


# Idaho Department of Environmental Quality Reuse Permit M-156-05

(Previous Permit No. M-156-04)

---

Stanley Sewer Association, Inc. (hereafter “permittee”) is hereby authorized to construct, install, and operate a reuse facility in accordance with (1) this permit; (2) IDAPA 58.01.17 “Recycled Water Rules”; (3) an approved plan of operation; and (4) all other applicable federal, state, and local laws, statutes, and rules. This permit is effective from the date of signature and expires on February 21, 2033.



---

Signature

February 21, 2023

---

Date

Troy Saffle

---

Regional Administrator  
Idaho Falls Regional Office  
Idaho Department of Environmental Quality

Idaho Department of Environmental Quality  
Idaho Falls Regional Office  
900 N. Skyline, Suite B, Idaho Falls, ID 83402  
(208) 528-2650

**Accessibility Services:** The Idaho Department of Environmental Quality will provide reasonable language access services and/or disability services for documents at no charge. To request an accommodation under Title VI of the Civil Rights Act of 1964 or Americans with Disabilities Act, contact DEQ's nondiscrimination coordinator at (208) 373-0271 or [accessibility@deq.idaho.gov](mailto:accessibility@deq.idaho.gov). Para obtener información en español, visite <https://www.deq.idaho.gov/about-us/accessibility/>.

*This page intentionally left blank for correct double-sided printing.*

## Table of Contents

1. Common Acronyms/Abbreviations and Definitions .....	5
2. Facility Information .....	7
3. Compliance Schedule for Required Activities .....	8
4. Permit Limits and Conditions .....	10
4.1 Management Unit Descriptions .....	10
4.2 Hydraulic Loading Limits .....	10
4.3 Constituent Loading Limits .....	10
4.4 Management Unit Buffer Zones .....	11
4.5 Other Permit Limits and Conditions .....	11
5. Monitoring Requirements .....	13
5.1 Recycled Water and Supplemental Irrigation Water Sampling and Analyses .....	13
5.1.1 Constituent Monitoring .....	13
5.1.2 Flow Monitoring .....	13
5.2 Groundwater Monitoring .....	14
5.2.1 Groundwater Monitoring Point Descriptions .....	14
5.2.2 Groundwater Monitoring, Sampling, and Analyses .....	14
5.3 Soil Monitoring .....	14
5.3.1 Soil Monitoring Unit Descriptions .....	14
5.3.2 Soil Monitoring, Sampling, and Analyses .....	15
5.4 Reserved .....	15
5.5 Lagoon Information .....	15
5.5.1 Lagoon Monitoring .....	15
6. Reporting Requirements .....	16
6.1 Annual Report Requirements .....	16
6.1.1 Due Date .....	16
6.1.2 Required Contents .....	16
6.1.3 Submittals .....	17
6.2 Emergency and Noncompliance Reporting .....	18
7. Reserved .....	19
8. Standard Permit Conditions .....	19
9. General Permit Conditions .....	21
9.1 Operations .....	21
9.1.1 Backflow Prevention .....	21
9.1.2 Restricted to Premises .....	21
9.1.3 Health Hazards, Nuisances, and Odors Prohibited .....	22
9.1.4 Solids Management .....	22
9.1.5 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801) .....	23
9.1.6 Plan of Operation (IDAPA 58.01.17.300.05) .....	23
9.1.7 Seepage Testing Requirements (IDAPA 58.01.16.493.02.c) .....	24
9.1.8 Ground Water Quality Rule (IDAPA 58.01.11) .....	24

9.2	Administrative.....	24
9.2.1	Permit Modification (IDAPA 58.01.17.700).....	24
9.2.2	Permit Transferable (IDAPA 58.01.17.800).....	24
9.2.3	Permit Revocation (IDAPA 58.01.17.920).....	25
9.2.4	Violations (IDAPA 58.01.17.930).....	25
9.2.5	Severability.....	25
10.	Other Applicable Laws.....	26
10.1	Owner Responsibilities for Well Use and Maintenance.....	26
10.1.1	Well Use.....	26
10.1.2	Well Maintenance.....	26
10.1.3	Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Groundwater Resource.....	26
11.	Site Maps.....	27
11.1	Regional Map.....	27
11.2	Facility Map.....	28

## 1. Common Acronyms/Abbreviations and Definitions

CA	compliance activity
COD	chemical oxygen demand
crop uptake	those constituents assimilated by the crop from the soil, and those from applied fertilizer, biosolids and other soil amendments, recycled water, irrigation water, and other sources. Crop uptake excludes those constituents assimilated from the atmosphere, such as gaseous nitrogen fixed by legumes. Crop uptake plus atmospheric assimilated constituents equals crop content.
DEQ	Idaho Department of Environmental Quality
director	DEQ director or designee unless otherwise specified
E <sub>i</sub>	irrigation efficiency
EPA	United States Environmental Protection Agency
FM	prefix for flow measurement/monitoring location, device, or method reporting serial number
GW	prefix for groundwater reporting serial number
IDAPA	Numbering designation for all administrative rules in Idaho promulgated according to the Idaho Administrative Procedure Act
IDWR	Idaho Department of Water Resources
IPDES	Idaho Pollutant Discharge Elimination System
IWR	irrigation water requirement — any combination of wastewater and supplemental irrigation water applied at rates commensurate to the moisture requirements of the crop, and calculated monthly during the growing season.
lb	pound
LG	prefix for lagoon reporting serial number
material change	a change in a document required by this permit that would impact DEQ's ability to ensure compliance and protect human health and the environment
µmhos/cm	micromhos per centimeter
MG	million gallons
mg/kg	milligram per kilogram
mg/L	milligram per liter
mL	milliliter

MU	management unit, prefix for management unit reporting environmental serial number
NPDES	National Pollutant Discharge Elimination System
N	nitrogen
ppm	parts per million
P	phosphorus
PO	plan of operation
QAPP	quality assurance project plan
responsible official	facility contact person authorized by the permittee to communicate with DEQ on behalf of the permittee on any matter related to the permit, including without limitation, the authority to communicate with and receive notices from DEQ regarding notices of violation or non-compliance, permit violations, permit enforcement, and permit revocation. The responsible official provides written certification of permit application materials, annual report submittals, and other information submitted to DEQ as required by the permit. Any notice to or communication with the responsible official is considered a notice to or communication with the permittee. The responsible official may designate an authorized representative to act as the facility contact person for any of the activities or duties related to the permit, except signing and certifying the permit application, which must be done by the responsible official. The authorized representative will act as the responsible official and will bind the permittee as described in this definition. Designation of the authorized representative must follow the requirements specified in section 6.1.3 of the permit.
SNRA	Sawtooth National Recreation Area
SSA	Stanley Sewer Association
SU	prefix for soil monitoring unit reporting serial number
SW	prefix for supplemental irrigation water reporting serial number
USFS	United States Forest Service
WW	prefix for wastewater reporting serial number
yr	year

## 2. Facility Information

Information Type	Information Specific to This Permit
Class or Type of recycled water	Municipal Class C Recycled Water
Method of treatment and reuse	Method of treatment: 3 facultative lagoons; hypochlorite disinfection. Method of reuse: Slow-rate reuse during the growing season to 103 acres of native vegetation with typical annual volume of 14.6 MG.
Collection and treatment system classification	Wastewater collection system classification: Class 1 Wastewater treatment system classification: Class 1 Wastewater Treatment: Land Application
Facility location	Approximately 2.3 miles south of Stanley, ID. Township 10 North, Range 13 East, Sections 21 and 22.
Facility mailing address	P.O. Box 71, Stanley, ID 83278
Facility responsible official and authorized representative	Responsible Official: Board President <a href="mailto:stanleysewer@yahoo.com">stanleysewer@yahoo.com</a>  (Currently Tom Peterson, (208) 720-9980, <a href="mailto:ptom200@gmail.com">ptom200@gmail.com</a> )  Notify DEQ within 10 days if a change in personnel occurs for any of the facility contacts. Changes in ownership or contact information must be reported to DEQ using the Owner Information Form, available at <a href="https://www.deq.idaho.gov/water-quality/wastewater/wastewater-treatment-and-collections/">https://www.deq.idaho.gov/water-quality/wastewater/wastewater-treatment-and-collections/</a> .
Groundwater	Groundwater depth ranges from 6' to 76' with seasonal variation influenced by snowfall. A major aquifer is not known to exist at the site and is assumed to be unconfined. Primary flow direction is from south to north.
Surface water	Salmon River, approximately 4,600 feet east of the site. Beneficial uses: cold water biota, primary contact recreation, salmonid spawning, domestic water supply, special resource water (IDAPA 58.01.02.130.03.S-63) Also agricultural water supply, industrial water supply, wildlife habitats, and aesthetics (IDAPA 58.01.02.100.03, 04, and 05).  Meadow Creek, approximately 810 feet northwest of the site. Meadow Creek normally only flows during spring runoff and into early summer. Beneficial uses: Agricultural water supply, industrial water supply, and aesthetics (IDAPA 58.01.02.100.03, 04, and 05). Presumed use protections for cold water aquatic life and contact recreation apply (IDAPA 58.01.02.101.a).

### 3. Compliance Schedule for Required Activities

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-156-01 Six months after permit issuance	<p><b>Plan of Operation (PO):</b> The permittee must submit to DEQ for review and approval a PO that reflects current operations and incorporates the requirements of this permit. The PO must comply with the applicable requirements stated in IDAPA 58.01.17.300.05 and must address applicable items in the most current Plan of Operations Checklist available.</p> <p>The PO must include the following site management plans or the permittee may submit the site management plans individually:</p> <ol style="list-style-type: none"> <li>1. Buffer zone plan.</li> </ol> <p>The PO must be updated as needed to reflect current operations. The permittee must notify DEQ of material changes to the PO and copies must be kept on site and made available to DEQ upon request.</p>
CA-156-02 Six months after permit issuance	<p><b>Quality Assurance Project Plan (QAPP):</b> The permittee must prepare and implement a QAPP that incorporates all monitoring and reporting required by this permit. A copy of the QAPP along with written notice that the permittee has implemented the QAPP must be provided to DEQ. The Permittee must follow the QAPP when collecting, analyzing, and reporting monitoring data submitted to DEQ.</p> <p>The QAPP must be designed to assist in planning for collecting, analyzing, and reporting all monitoring in support of this permit and in explaining data anomalies when they occur. At a minimum, the QAPP must include the following:</p> <ol style="list-style-type: none"> <li>1. Details on the number of measurements, number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements.</li> <li>2. Maps indicating the location of each monitoring and sampling point.</li> <li>3. Qualification and training of personnel.</li> <li>4. Names, addresses, and telephone numbers of the laboratories used by or proposed to be used by the permittee.</li> <li>5. Example formats and tables that will be used by the permittee to summarize and present all data in the annual report.</li> </ol> <p>The format and content of the QAPP should adhere to the recommendations and references in the Quality Assurance and Data Processing sections of the reuse guidance.</p> <p>The permittee must amend the QAPP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAPP. The permittee must notify DEQ of material changes to the QAPP and copies must be kept on site and made available to DEQ upon request.</p>



Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description								
CA-156-03 As specified	<p><b>Seepage Testing:</b> The following table shows the date by which the permittee must complete seepage testing on the specified lagoons:</p> <table border="1" data-bbox="461 447 1349 611"> <thead> <tr> <th>Lagoon:</th> <th>Seepage Test Due Date:</th> </tr> </thead> <tbody> <tr> <td>LG-156-01 (Lagoon #1)</td> <td>2026</td> </tr> <tr> <td>LG-156-02 (Lagoon #2)</td> <td>2026</td> </tr> <tr> <td>LG-156-03 (Lagoon #3)</td> <td>2026</td> </tr> </tbody> </table> <p>Submit to DEQ for review and approval a proposed schedule and procedure for performing the required seepage tests at least 45 days before to the planned seepage test. The seepage test procedures must be sealed by the Idaho licensed professional engineer or professional geologist in responsible charge for the test.</p> <p>Seepage tests must be completed according to the procedures approved by DEQ. The seepage test report must be sealed by the person in responsible charge and submitted within 90 days after completion of the seepage test.</p> <p>Allowable seepage rates can be found in IDAPA 58.01.16.493.03. Requirements for lagoons leaking above the allowable amount are outlined in IDAPA 58.01.16.493.04.</p>	Lagoon:	Seepage Test Due Date:	LG-156-01 (Lagoon #1)	2026	LG-156-02 (Lagoon #2)	2026	LG-156-03 (Lagoon #3)	2026
Lagoon:	Seepage Test Due Date:								
LG-156-01 (Lagoon #1)	2026								
LG-156-02 (Lagoon #2)	2026								
LG-156-03 (Lagoon #3)	2026								
CA-156-04 October 31, 2025	<p><b>Lagoon Site Fencing and Posting Improvements:</b> The permittee must repair or replace damaged sections of perimeter fence surrounding the lagoon treatment system. Warning signs must be placed every 75 feet along the eastern perimeter of the lagoon site. SSA must submit documentation to DEQ demonstrating the improvements by October 31, 2025.</p>								
CA-156-05 April 1, 2026.	<p><b>Licensed Operator:</b> The wastewater treatment facility and reuse system must be operated by personnel certified and licensed in the State of Idaho wastewater operator training program at the operator class level specified in IDAPA 58.01.16.203 and properly trained to operate and maintain the system. The permittee must report any changes to the responsible charge operator or substitute responsible charge operator to DEQ within 10 days using the Public Wastewater System Operator Licensure Record Form, available at <a href="https://www.deq.idaho.gov/water-quality/wastewater/wastewater-treatment-and-collections/">https://www.deq.idaho.gov/water-quality/wastewater/wastewater-treatment-and-collections/</a>. The permittee must hire or contract a licensed operator and provide an updated form no later than April 1, 2026.</p>								
CA-156-06 December 31, 2029	<p><b>Forest Service Special Use Permit:</b> The permittee must submit to DEQ a copy of an updated USFS special use permit issued to SSA before land application can be allowed to continue past the expiration date of the current special use permit.</p>								
CA-156-07 As specified	<p><b>Influent Flow Meter Improvement Plan:</b> The permittee must submit to DEQ for review and approval an influent flow meter improvement plan no later than 18 months after permit issuance. The plan account for complete, accurate, and reliable influent flow data for all inputs to the wastewater treatment system, including the SSA collection system, the SNRA collection system, and the RV dump station. The plan should also address safe and reliable data collection during the winter months.</p> <p>Upon DEQ approval, the permittee must implement any improvements deemed necessary from the plan to provide complete and accurate flow data within 6 months.</p>								

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-156-08 One year prior to permit expiration	<b>Pre-application Conference:</b> If the permittee intends to continue operating the reuse facility beyond the expiration date of this permit, the permittee must contact DEQ and schedule a pre-application conference to discuss the compliance status of the facility and the content required for the reuse permit application package.
CA-156-09 Six months prior to permit expiration	<b>Permit Renewal Application:</b> The permittee must submit to DEQ a complete permit renewal application package that fulfills the requirements specified in CA-156-08 and identified at the pre-application conference.

## 4. Permit Limits and Conditions

### 4.1 Management Unit Descriptions

Serial Number	Description	Irrigation System Type and Irrigation Efficiency (E <sub>i</sub> )	Maximum Acres <sup>a</sup> Allowed
MU-156-01	Reuse Site	Wheel lines (E <sub>i</sub> = 0.70)	103
Total acreage			103

- a. Maximum acres represent the total permitted acreage of the MU as provided by the permittee. If the permittee uses less acreage in any season or year, then loading rates must be presented and compliance will be determined based on the actual acreage used during each season or year.

### 4.2 Hydraulic Loading Limits

Serial Number	Growing Season Hydraulic Loading <sup>a,b</sup>	Nongrowing Season Hydraulic Loading
MU-156-01	15 in/acre	Not allowed

- a. Permittee must calculate per-acre loading based on actual acreage used.  
 b. Permittee must irrigate MU-156-01 as uniformly as possible and in accordance with the most recently approved Irrigation Management Plan.

### 4.3 Constituent Loading Limits

Serial Number	Constituent Loading from All Sources
	Nitrogen (lb/acre) <sup>a</sup>
MU-156-01	50

- a. Permittee must calculate per-acre loading based on actual acreage used.

#### 4.4 Management Unit Buffer Zones

Serial Number	Buffer Distances (feet) from Management Units <sup>a</sup>					
	Public Water Supplies	Private Water Supplies	Inhabited Dwellings	Permanent and Intermittent Surface Water	Irrigation Ditches and Canals	Areas Accessible to the Public
MU-156-01	1,000	500	300	100	50	0

- a. Any mitigation measures to reduce the Buffer Distances specified above must be approved by DEQ in writing prior to construction, implementation, or use.

#### 4.5 Other Permit Limits and Conditions

Category	Permit Limits and Conditions
Growing season	May 1 through October 31 (184 days)
Nongrowing season	November 1 through April 30 (181 days)
Reporting year for annual loading rates	January 1 through December 31
Operator certification and endorsement	The wastewater treatment facility and reuse system must be operated by personnel certified and licensed in the State of Idaho wastewater operator training program at the operator class level specified in IDAPA 58.01.16.203 and properly trained to operate and maintain the system.
Disinfection limits in recycled water	Class C: The median number of total coliform organisms must not exceed 23 total coliform organisms/100 mL, as determined from the bacteriological results of the last five days for which analyses have been completed. No sample may exceed 230 total coliform organisms/100 mL in any confirmed sample.
Crop or vegetation allowed	Native vegetation per USFS agreement.
Grazing	Prior to grazing, the permittee must submit a grazing management plan and receive written approval from DEQ.
Posting	Signs must read "Warning: Recycled Water—Do Not Enter," or equivalent. Signs to be posted every 500 feet and at each corner of the outer perimeter of the irrigated site. Signs are required where management unit border areas are accessible to the public. Signage is required around the lagoon site in accordance with IDAPA 58.01.16.493.09.c.iii.
Fencing	Fencing required around MU-156-01, LG-156-01, LG-156-02, LG-156-03 must prevent livestock from entering and discourage trespassing.
Construction plans	Pursuant to Idaho Code §39-118, IDAPA 58.01.16, and IDAPA 58.01.17, detailed plans and specifications must be submitted to DEQ for review and approval before construction, modification, or expansion of any wastewater treatment, storage, conveyance structures, groundwater monitoring wells, or reuse facility. Inspection requirements must be satisfied, and within 30 days of completion of construction, the permittee must submit as-built plans or a letter from an Idaho professional engineer certifying the facilities or structures were constructed in substantial accordance with the approved plans and specifications.

<b>Category</b>	<b>Permit Limits and Conditions</b>
Records retention requirements	Keep records generated to meet the requirements of this permit for the duration of the permit, including administrative extensions, plus two years.
Mainline Drain Valve	Discharge from the mainline drain valve must be distributed as specified in the Plan of Operations to prevent ponding, erosion, or flooding at the point of discharge.
Flow Measurement Devices	Flow measurement devices used to directly or indirectly measure wastewater, recycled water, and supplemental irrigation water flows applied to each management unit must be calibrated or verified in accordance with the device manufacturer's specifications and with the permittee's QAPP.

## 5. Monitoring Requirements

### 5.1 Recycled Water and Supplemental Irrigation Water Sampling and Analyses

#### 5.1.1 Constituent Monitoring

Monitoring Point Serial Number and Location	Sample Description	Sample Type and Frequency	Constituents (mg/L unless otherwise specified)
WW-156-01 Irrigation pump sample port (Inside pump house)	Recycled water to MU-156-01	Grab/biweekly (during periods of use) <sup>a</sup>	Total coliform (CFU/100 mL)
		Grab/weekly (during periods of use)	Free chlorine residual (mg/L)
		Grab/monthly (during periods of use)	Total nitrogen (mg/L) Total phosphorus (mg/L)

- a. SSA must collect and analyze at least five (5) recycled water samples for total coliform in each growing season.

#### 5.1.2 Flow Monitoring

Management Unit or Flow Measurement Serial Number and Location	Sample Description	Sample Type and Frequency	Parameters, each MU or FM
FM-156-01 Ultrasonic flow meter on SNRA Parshall Flume	Wastewater influent from SNRA	Daily meter reading during the growing season, until implementation of Flow Meter Improvement Plan as specified in CA-156-07.  Monthly and annual compilation of data.	Volume (MG/month) Volume (MG/year)
FM-156-02 Electromagnetic flowmeter on SSA force main	Wastewater influent from SSA	Daily meter reading during the growing season, until implementation of Flow Meter Improvement Plan as specified in CA-156-07.  Monthly and annual compilation of data.	Volume (MG/month) Volume (MG/year)
FM-156-03 Electromagnetic flowmeter on recycled water irrigation line	Recycled water flow to MU-156-01	Daily meter reading during use.  Monthly and annual compilation of data.	Volume (MG/month) Volume (MG/year)

## 5.2 Groundwater Monitoring

### 5.2.1 Groundwater Monitoring Point Descriptions

Monitoring Point Serial Number	Common Designation	Well Type	Gradient Location
GW-156-01	MW 1	Monitoring well	Upgradient (South)
GW-156-02	MW 2	Monitoring well	Mid-gradient (NW)
GW-156-03	MW 3	Monitoring well	Downgradient (NE)

### 5.2.2 Groundwater Monitoring, Sampling, and Analyses

Monitoring Point Serial Number	Sampling Point Description	Sample Type and Frequency	Constituents (mg/L unless otherwise specified)
GW-156-01 GW-156-02 GW-156-03	Monitoring wells	Field measurements annually in September	Water table elevation (feet) Water table depth (feet) Specific conductance/electrical conductivity ( $\mu\text{mhos/cm}$ ) Temperature ( $^{\circ}\text{C}$ ) pH (Standard Units)
GW-156-01 GW-156-02 GW-156-03	Monitoring wells	Unfiltered grab sample annually in September	Nitrate-nitrogen Chloride Dissolved manganese

## 5.3 Soil Monitoring

### 5.3.1 Soil Monitoring Unit Descriptions

Monitoring Point Serial Number	Description	Associated Management Unit
SU-156-01	Reuse Site	MU-156-01

### 5.3.2 Soil Monitoring, Sampling, and Analyses

Monitoring Point Serial Number	Sample Type	Sample Frequency	Constituents (Units in mg/kg Soil Unless Otherwise Specified)
SU-156-01	Composite samples <sup>a</sup>	Annually, May (prior to irrigation)	Electrical conductivity ( $\mu$ mhos/cm in saturated paste extract) Nitrate-nitrogen Ammonium-nitrogen Plant available phosphorus pH (standard units)

- a. The number of sample locations for each SU must be specified in the QAPP required by this permit. At each location, samples must be obtained from three depths: 0–12 inches, 12–24 inches, and 24–36 inches or refusal. The samples obtained from each depth must be composited by depth to yield three composite samples for each soil monitoring unit (one composite sample for each depth).

### 5.4 Reserved

### 5.5 Lagoon Information

Serial number	Description	Surface Area, acres	Maximum Operating Volume, MG
LG-156-01	Lagoon #1	4.8	7.0
LG-156-02	Lagoon #2	4.8	6.7
LG-156-03	Lagoon #3	5.2	9.5

#### 5.5.1 Lagoon Monitoring

Monitoring Point Serial Number <sup>a</sup>	Sample Type	Sample Frequency
LG-156-01 LG-156-02 LG-156-03	Depth (to nearest inch)	Monthly (May through November). <sup>b</sup>

- a. Lagoon depth measurement locations and methods must be specified in the QAPP required by this permit.
- b. Depth measurements must be made in the first week of each month.

## 6. Reporting Requirements

### 6.1 Annual Report Requirements

The permittee must submit to DEQ an annual report prepared by a competent environmental professional covering the previous reporting year.

#### 6.1.1 Due Date

The annual report is due no later than **March 31** of each year, which must cover the previous reporting year.

#### 6.1.2 Required Contents

The annual report must include the following:

1. Detailed results of the required monitoring as described in section 5 of this permit. The report must present all monitoring data in summary tables to expedite review. If the permittee monitors any parameter for compliance purposes more frequently than required by this permit, the results of this monitoring must be included in the calculation and reporting of the data submitted in the annual report.
2. A brief interpretive discussion of the results of all required monitoring data as specified by section 5. The discussion must address data quality objectives, validation, and verification; explain what the data say about permit compliance; and reuse facility environmental impacts. The reporting year for this permit is specified in section 4.5.
3. Status of all work described in section 3 of this permit.
4. Results of all backflow testing, repairs, and replacements required by section 9.1.1 of this permit.
5. Discussion of major maintenance activities such as major equipment replacement, lagoon liner maintenance, and wastewater treatment and reuse facility maintenance.
6. A summary of all noncompliance events that occurred during the reporting year. Examples of noncompliance events that must be discussed include, but are not limited to: exceedance of permit limits, complaints, missed monitoring events, incorrect monitoring dates or frequencies, dry monitoring wells, uncontained spills causing runoff, construction without DEQ engineering plan approval, construction without engineering inspection, and reporting incorrect acreage.
7. Laboratory analytical reports that show results, analytical methods, and practical quantitation limits for monitoring specified in section 5 of the permit. Chain of custody forms, supporting information for laboratory analytical reports, and quality assurance documentation must be available for review upon request by DEQ.
8. The calculations and results for the parameters in the following table:



Monitoring Point Serial Number	Parameter (Calculate for each MU)	Units
MU-156-01	Recycled water loading rate	MG/month Inches/month
	Recycled water nitrogen and phosphorus loading rates	lb/(acre-year)
Other Reporting Requirements: <ul style="list-style-type: none"> <li>• Report actual site acreage used for recycled water land application. All loading rates must be calculated based on the actual acreage used.</li> <li>• Include copies of irrigation system operation log sheets.</li> </ul>		

### 6.1.3 Submittals

All applications, annual reports, or other information submitted to DEQ as required by this permit must be signed and certified as follows:

- Permit applications must be signed by the responsible official as described below:
  - For a corporation by a responsible corporate officer.
  - For a partnership or sole proprietorship by a general partner or the proprietor, respectively.
  - For a municipality, state, federal, Indian tribe, or other public agency by either the principal executive officer, ranking elected official, or a person of decision-making authority who can legally bind the permittee with respect to the permit.
- Annual reports and other information required by this permit must be signed by the responsible official or by a duly authorized representative of that person. A person is a duly authorized representative only if all of the following are true:
  - The authorization is made in writing by the responsible official.
  - The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual having overall responsibility for environmental matters for the company.
  - The written authorization is submitted to DEQ.

Submit all applications, annual reports, and other information required by this permit to the following DEQ regional office at this address:

Engineering Manager  
 Idaho Department of Environmental Quality  
 Idaho Falls Regional Office  
 900 North Skyline, Suite B  
 Idaho Falls, ID 83402  
 Tel: (208) 528-2650

The annual report, or any other data or monitoring information submitted to DEQ, must include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative:

*"I certify that the information provided in this submittal was prepared in conformance with the Quality Assurance Project Plan required by this permit and is to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01 or other enforcement action as provided for under Idaho law."*

Permit applications must include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official:

*"I certify that the information provided in this submittal is, to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01, non-issuance of the permit, or other enforcement action as provided for under Idaho law."*

Other information submitted to DEQ as required by the permit must include the above certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative.

## **6.2 Emergency and Noncompliance Reporting**

The permittee must report noncompliance incidents to DEQ's regional office at (208) 528-2650.

The permittee may also be required to report unauthorized discharges to surface waters to DEQ's IPDES program. The DEQ IPDES hotline is (833) IPDES24 or (833) 473-3724.

In case of public health emergencies, the permittee should call the 24-hour Idaho Emergency Medical Services Communications Center number at (800) 632-8000.

Section 8 of this permit and IDAPA 58.01.17.500.06 provide the reporting requirements for facilities.

The permittee must report all instances of permit non-compliance that may endanger public health or the environment and unauthorized discharges to surface waters of the State of Idaho to DEQ's regional office by telephone (phone numbers provided in this section) within 24 hours from the time the permittee becomes aware of these events at the phone numbers provided in this section.

The permittee must provide a written follow-up to the DEQ regional office within five days from the time the permittee became aware of the permit non-compliance or unauthorized discharge.

## 7. Reserved

## 8. Standard Permit Conditions

The following standard permit conditions are included as terms of this permit as required by the "Recycled Water Rules," (IDAPA 58.01.17.500).

### 500. STANDARD PERMIT CONDITIONS.

The following conditions shall apply to and be included in all permits. (3-31-22)

- 01. Compliance Required.** The permittee shall comply with all conditions of the permit. (3-31-22)
- 02. Renewal Responsibilities.** If the permittee intends to continue operation of the permitted facility after the expiration of an existing permit, the permittee shall apply for a new permit in accordance with these rules. (3-31-22)
- 03. Operation of Facilities.** The permittee shall at all times properly maintain and operate all structures, systems, and equipment for treatment, control and monitoring, which are installed or used by the permittee to achieve compliance with the permit or these rules. (3-31-22)
- 04. Provide Information.** The permittee shall furnish to the Director within a reasonable time, any information including copies of records, which may be requested by the Director to determine whether cause exists for modifying, revoking, re-issuing, or terminating the permit, or to determine compliance with the permit or these rules. (3-31-22)
- 05. Entry and Access.** The permittee shall allow the Director, consistent with Title 39, Chapter 1, Idaho Code, to:
  - a.** Enter the permitted facility. (3-31-22)
  - b.** Inspect any records that must be kept under the conditions of the permit. (3-31-22)
  - c.** Inspect any facility, equipment, practice, or operation permitted or required by the permit. (3-31-22)
  - d.** Sample or monitor for the purpose of assuring permit compliance, any substance or any parameter at the facility. (3-31-22)
- 06. Reporting.** The permittee shall report to the Director under the circumstances and in the manner specified in this section: (3-31-22)
  - a.** In writing at least thirty (30) days before any planned physical alteration or addition to the permitted facility or activity if that alteration or addition would result in any significant change in information that was submitted during the permit application process. When the alteration or addition results in a need for a major modification, such alteration or addition shall not be made prior to Department approval issued in accordance with these rules. (3-31-22)
  - b.** In writing thirty (30) days before any anticipated change which would result in noncompliance with any permit condition or these rules. (3-31-22)

c. Orally within twenty-four (24) hours from the time the permittee became aware of any noncompliance which may endanger the public health or the environment at telephone numbers provided in the permit by the Director. (3-31-22)

d. In writing as soon as possible but within five (5) days of the date the permittee knows or should know of any noncompliance unless extended by the Department. This report shall contain: (3-31-22)

i. A description of the noncompliance and its cause; (3-31-22)

ii. The period of noncompliance including to the extent possible, times and dates and, if the noncompliance has not been corrected, the anticipated length of time it is expected to continue; and (3-31-22)

iii. Steps taken or planned, including timelines, to reduce or eliminate the continuance or reoccurrence of the noncompliance. (3-31-22)

e. In writing as soon as possible after the permittee becomes aware of relevant facts not submitted or incorrect information submitted, in a permit application or any report to the Director. Those facts or the correct information shall be included as a part of this report. (3-31-22)

**07. Minimize Impacts.** The permittee shall take all necessary actions to eliminate and correct any adverse impact on the public health or the environment resulting from permit noncompliance. (3-31-22)

**08. Compliance with "Ground Water Quality Rule."** Permits issued pursuant to these rules shall require compliance with IDAPA 58.01.11, "Ground Water Quality Rule." (3-31-22)

## **9. General Permit Conditions**

The following general permit conditions are based on the cited rules at the time of issuance and are enforceable as part of this permit. Note that the rules cited in this section, and elsewhere in this permit, are supplemented by the rules themselves. Rules applicable to your facility are enforceable whether or not they appear in this permit.

### **9.1 Operations**

#### **9.1.1 Backflow Prevention**

Reuse facilities with existing or planned cross-connections or interconnections between the recycled water system and any water supply (potable or nonpotable) or surface water, must have backflow prevention assemblies, devices, or methods as required by applicable rule or as specified in this permit and approved by DEQ.

For public water systems, backflow assemblies must meet the requirements of IDAPA 58.01.08.543. Assemblies must be adequately maintained and must be tested annually by a certified backflow assembly tester, and repaired or replaced as necessary to maintain operational status.

For domestic water supply wells, backflow prevention devices must meet the requirements of IDAPA 07.02.04 and must be adequately operated and maintained.

Irrigation water supply wells must meet the requirements of IDAPA 37.03.09.36 for preventing any waste or contamination of the groundwater resource. Backflow prevention assemblies or devices used to protect the groundwater must be adequately operated and maintained.

Discharge of recycled water to surface water is regulated by the DEQ or EPA. An IPDES or NPDES permit is required for any discharge to surface water and backflow prevention must be implemented to prevent any unauthorized discharge. Backflow prevention assemblies or devices used to protect surface water must be adequately operated and maintained.

Records of all testable backflow assembly test results, repairs, and replacements must be kept at the reuse facility along with other operational records, and must be discussed in the annual report and made available for inspection by DEQ. Other approved means of backflow prevention, such as siphons and air-gap structures that cannot be tested, must be maintained in operable order.

#### **9.1.2 Restricted to Premises**

Wastewaters or recharge waters applied to the land surface must be restricted to the premises of the application site. Wastewater discharges to surface water require an IPDES or NPDES permit (IDAPA 58.01.16.600.02).

### 9.1.3 Health Hazards, Nuisances, and Odors Prohibited

Health hazards, nuisances, and odors are prohibited as follows:

Wastewater must not create a public health hazard or nuisance condition (IDAPA 58.01.16.600.03).

No person shall allow, suffer, cause, or permit the emission of odorous gases, liquids, or solids into the atmosphere in such quantities as to cause air pollution (IDAPA 58.01.01.776.01).

Air Pollution defined as the presence in the outdoor atmosphere of any air pollutant or combination thereof in such quantity of such nature and duration and under such conditions as would be injurious to human health or welfare, to animal or plant life, or to property, or to interfere unreasonably with the enjoyment of life or property (IDAPA 58.01.01.006.06).

### 9.1.4 Solids Management

**Biosolids** are the nutrient-rich organic materials resulting from the treatment of sewage sludge. When treated and processed, sewage sludge becomes biosolids that can be safely recycled and applied as fertilizer to sustainably improve and maintain productive soils and stimulate plant growth.

Biosolids generated from sewage sludge are regulated by DEQ or EPA under 40 CFR Part 503 and require a DEQ-approved sludge disposal plan as outlined in IDAPA 58.01.16.650. Contact DEQ before to applying biosolids at any permitted reuse facility.

**Sludge** is the semi-liquid mass produced and removed by wastewater treatment processes. This does not include grit, garbage, and large solids.

Sludge may be generated by wastewater treatment processes at municipal and industrial facilities. A DEQ-approved sludge disposal plan, as outlined in IDAPA 58.01.16.650, may be required.

**Solid waste** is any garbage or refuse, sludge from a waste water treatment plant, water supply treatment plant, or air pollution control facility and other discarded material including solid, liquid, semi-solid, or contained gaseous material resulting from industrial, commercial, mining, and agricultural operations and from community activities, but does not include solid or dissolved materials in domestic sewage, or solid or dissolved material in irrigation return flows or industrial discharges that are point sources subject to permits under Section 402 of the Federal Water Pollution Control Act, as amended or source, special nuclear, or by-product material as defined by the Atomic Energy Act of 1954, as amended.

Solid waste does not include inert wastes, manures and crop residues ultimately returned to the soils at agronomic rates, and any agricultural solid waste that is managed and regulated pursuant to rules adopted by the Idaho Department of Agriculture. DEQ reserves the right to use existing authorities to regulate agricultural waste that impacts human health or the environment.

Solid waste is regulated under the "Solid Waste Management Rules" (IDAPA 58.01.06). Wastes otherwise regulated by DEQ (i.e., this permit) are not regulated under IDAPA 58.01.06.

**Waste solids** include sludge and wastes otherwise regulated by DEQ according with IDAPA 58.01.06.001.03.a.xii. Waste solids may include vegetative waste, silt and mud containing organic matter, and other non-inert solid wastes.

Inert wastes are defined as non-combustible, nonhazardous, and non-putrescible solid wastes that are likely to retain their physical and chemical structure and have a de minimis potential to generate leachate under expected conditions of disposal, which includes resistance to biological attack.

Waste solids require a DEQ-approved sludge disposal plan as outlined in IDAPA 58.01.16.650.

### **9.1.5 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801)**

Temporary cessation of operations and closure must be addressed as follows:

**01. Temporary Cessation.** A permittee shall implement any applicable conditions specified in the permit for temporary cessation of operations. When the permit does not specify applicable temporary cessation conditions, the permittee shall notify the Director prior to a temporary cessation of operations at the facility greater than sixty (60) days in duration and any cessation not for regular maintenance or repair. Cessation of operations necessary for regular maintenance or repair of a duration of sixty (60) days or less are not required to notify the Department under this section. All notifications required under this section shall include a proposed temporary cessation plan that will ensure the cessation of operations will not pose a threat to human health or the environment. (3-31-22)

**02. Closure.** A closure plan shall be required when a facility is closed voluntarily and when a permit is revoked or expires. A permittee shall implement any applicable conditions specified in the permit for closure of the facility. Unless otherwise directed by the terms of the permit or by the Director, the permittee shall submit a closure plan to the Director for approval at least ninety (90) days prior to ceasing operations. The closure plan shall ensure that the closed facility will not pose a threat to human health and the environment. Closure plan approval may be conditioned upon a permittee's agreement to complete such site investigations, monitoring, and any necessary remediation activities that may be required. (3-31-22)

### **9.1.6 Plan of Operation (IDAPA 58.01.17.300.05)**

The PO must comply with the following:

**05. Reuse Facility Operation and Maintenance Manual or Plan of Operations.** A facility's operation and maintenance manual must contain all system components relating to the reuse facility in order to comply with IDAPA 58.01.16 "Wastewater Rules," Section 425. Manuals and manual amendments are subject to the review and approval provision therein. In addition to the content required by IDAPA 58.01.16.425, manuals for reuse facilities shall include, if applicable: operation and management responsibility, permits and standards, general plant description, operation and control of unit operations, land application site maps, wastewater characterization, cropping plan, hydraulic loading rate, constituent loading rates, compliance activities, seepage rate testing, site management plans, monitoring, site operations and maintenance, solids handling and processing, laboratory testing, general maintenance, records and reports, store room and inventory, personnel, an emergency operating plan, and any other information required by the Department. (3-31-22)

### **9.1.7 Seepage Testing Requirements (IDAPA 58.01.16.493.02.c)**

**Subsequent Tests.** All lagoons covered under these rules must be seepage tested by an Idaho licensed professional engineer, an Idaho licensed professional geologist, or by individuals under their supervision every ten (10) years after the initial testing. (3-8-09)

### **9.1.8 Ground Water Quality Rule (IDAPA 58.01.11)**

The permittee must comply with the requirements of the "Ground Water Quality Rule" (IDAPA 58.01.11).

## **9.2 Administrative**

Requirements for administration of the permit are defined as follows.

### **9.2.1 Permit Modification (IDAPA 58.01.17.700)**

**01. Modification of Permits.** A permit modification may be initiated by the receipt of a request for modification from the permittee, or may be initiated by the Department if one (1) or more of the following causes for modification exist: (3-31-22)

**a.** Alterations. There are material and substantial alterations or additions to the permitted facility or activity which occurred after permit issuance which justify the application of permit conditions that are different or absent in the existing permit. (3-31-22)

**b.** New standards or regulations. The standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued. (3-31-22)

**c.** Compliance schedules. The Department determines good cause exists for modification of a compliance schedule or terms and conditions of a permit. (3-31-22)

**d.** Non-limited pollutants. When the level of discharge of any pollutant which is not limited in the permit exceeds the level which may cause an adverse impact to surface or ground waters. (3-31-22)

**e.** To correct technical mistakes, such as errors in calculation, or mistaken interpretations of law made in determining permit conditions. (3-31-22)

**f.** When a treatment technology proposed, installed, and properly operated and maintained by the permittee fails to achieve the requirements of the permit. (3-31-22)

### **9.2.2 Permit Transferable (IDAPA 58.01.17.800)**

**01. General.** A permit may be transferred only upon approval of the Department. No transfer is required for a corporate name change as long as the secretary of state can verify that a change in name alone has occurred. An attempted transfer is not effective for any purpose until approved in writing by the Department. (3-31-22)



### 9.2.3 Permit Revocation (IDAPA 58.01.17.920)

**01. Conditions for Revocation.** The Director may revoke a permit if the permittee violates any permit condition or these rules, or the Director becomes aware of any omission or misrepresentation of condition or information relied upon when issuing the permit. (3-31-22)

**02. Notice of Revocation.** Except in cases of emergency, the Director shall issue a written notice of intent to revoke to the permittee prior to final revocation. Revocation shall become final within thirty-five (35) days of receipt of the notice by the permittee, unless within that time the permittee requests an administrative hearing in writing. The hearing shall be conducted in accordance with IDAPA 58.01.23, "Contested Case Rules and Rules for Protection and Disclosure of Records." (3-31-22)

**03. Emergency Action.** If the Director finds the public health, safety or welfare requires emergency action, the Director shall incorporate findings in support of such action in a written notice of emergency revocation issued to the permittee. Emergency revocation shall be effective upon receipt by the permittee. Thereafter, if requested by the permittee in writing, the Director shall provide the permittee a revocation hearing and prior notice thereof. Such hearings shall be conducted in accordance with IDAPA 58.01.23, "Contested Case Rules and Rules for Protection and Disclosure of Records." (3-31-22)

**04. Revocation and Closure.** A permittee shall perform the closure requirements in a permit, the closure requirements of these rules, and complete all closure plan activities notwithstanding the revocation of the permit. (3-31-22)

### 9.2.4 Violations (IDAPA 58.01.17.930)

Any person violating any provision of these rules or any permit or order issued thereunder shall be liable for a civil penalty not to exceed ten thousand dollars (\$10,000) or one thousand dollars (\$1,000) for each day of a continuing violation, whichever is greater. In addition, pursuant to Title 39, Chapter 1, Idaho Code, any willful or negligent violation may constitute a misdemeanor. (3-31-22)

### 9.2.5 Severability

The provisions of this permit are severable, and if a provision or its application is declared invalid or unenforceable for any reason, that declaration will not affect the validity or enforceability of the remaining provisions.

## **10. Other Applicable Laws**

DEQ may refer enforcement of the following provisions to the state agency authorized to enforce that rule. The permittee must comply with all applicable provisions identified in this section. Compliance with this permit does not relieve the permittee from applicable requirements in other federal, state, and local laws, statutes, and rules.

### **10.1 Owner Responsibilities for Well Use and Maintenance**

#### **10.1.1 Well Use**

The well owner must not operate any well in a manner that causes waste or contamination of the groundwater resource. Failure to operate, maintain, knowingly allow the construction of any well in a manner that violates these rules, or failure to repair or properly decommission (abandon) any well as herein required will subject the well owner to civil penalties as provided by statute. See IDAPA 37.03.09.036.01 and consult the Idaho Department of Water Resources (IDWR) for more information.

#### **10.1.2 Well Maintenance**


The well owner must maintain the well to prevent waste or contamination of groundwaters through leaky casings, pipes, fittings, valves, pumps, seals, or through leakage around the outside of the casings, whether the leakage is above or below the land surface. Any person owning or controlling a noncompliant well must have the well repaired by a licensed well driller under a permit issued by the IDWR director according to the applicable rules. See IDAPA 37.03.09.036.02 and consult IDWR for more information.

#### **10.1.3 Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Groundwater Resource**

The well owner must have any well shown to pose a threat to human health and safety or cause contamination of the groundwater resource immediately repaired or decommissioned (abandoned) by a licensed well driller under a permit issued by the IDWR director according to the applicable rules. See IDAPA 37.03.09.036.06 and consult IDWR for more information.

# 11. Site Maps

## 11.1 Regional Map



## 11.2 Facility Map

