

**DEQ's Response to Comments  
Proposed Rule Docket No. 58-0103-1901**

1. Public Health District 4 (Central District Health)	
---	--

Comment #	Rule Section/ Subject Matter	Commenter	Comment Summary	Response
1	Section 009.04.d.ii.	1	<p>The system sand, Manufactured Medium Sand (MMS) associated with these Proprietary Treatment Systems is a component of the system and how they were tested at NSF. In section 009.04.e the way it is worded makes it sound like the MMS is a component of the trench or bed. I am concerned that the system sand component of the treatment system might get confused with sand used for backfilling in an in trench sand filter design.</p> <p>Current wording:                      "Separation between the bottom of the manufactured medium sand component of the trench or bed to limiting layers, ..."</p> <p>I propose the following wording to make things more clear:                      "Separation between the bottom of the manufactured medium sand component of the Proprietary Wastewater Treatment System to limiting layers, ..."</p>	This change is acceptable and will provide additional clarification.
N/A	004 006 009	N/A	DEQ revised Sections 004, 006, and 009 to correct publication errors overlooked during review of the proof copy proposed rule.	N/A