

United States Environmental Protection Agency
 Region 10
 1200 Sixth Avenue Suite 900
 Seattle, Washington 98101-3140

**Authorization to Discharge Under the
 National Pollutant Discharge Elimination System**

In compliance with the provisions of the Clean Water Act, 33 USC §1251 *et seq.*, as amended by the Water Quality Act of 1987, P.L. 100-4, the "Act",

**City of Genesee
 Wastewater Treatment Plant**

P.O. Box 38
 Genesee, Idaho 83832

is authorized to discharge from the Genesee Wastewater Treatment Plant facility located in Genesee, ID, at the following location(s):

Outfall	Receiving Water	Latitude	Longitude
001	Cow Creek	46° 32' 26" N	116° 56' 30" W


in accordance with discharge point(s), effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective July 1, 2017

This permit and the authorization to discharge shall expire at midnight, June 30, 2022

The permittee shall reapply for a permit reissuance on or before January 1, 2022, 180 days before the expiration of this permit if the permittee intends to continue operations and discharges at the facility beyond the term of this permit.

Signed this 26 day of April, 2017


 Christine Psyk, Acting Director
 Office of Water and Watersheds

Schedule of Submissions

Item	Due Date
Discharge Monitoring Reports (DMR)	DMRs are due monthly and must be postmarked on or before the 20 th of the month following the monitoring month.
Quality Assurance Plan (QAP)	The permittee must provide EPA and IDEQ with written notification that the Plan has been developed and implemented within 180 days after the effective date of the final permit (see Part II.B of this permit). The Plan must be kept on site and made available to EPA and IDEQ upon request.
Operation and Maintenance (O&M) Plan	The permittee must provide EPA and IDEQ with written notification that the Plan has been developed and implemented within 180 days after the effective date of the final permit (see Part II.A of this permit). The Plan must be kept on site and made available to EPA and IDEQ upon request.
NPDES Application Renewal	The application must be submitted at least 180 days before the expiration date of the permit (see Part V.B of this permit).
Surface Water Monitoring Report	The report must be submitted with the next permit application (see Part I.C of this permit).
Compliance Schedule	Compliance with ammonia effluent limits must be achieved by eight years after the effective date of the permit (see Part II.C). Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date (see Part III.K of this permit).
Twenty-Four Hour Notice of Noncompliance Reporting	The permittee must report certain occurrences of noncompliance by telephone within 24 hours from the time the permittee becomes aware of the circumstances (see Paragraph I.B.5 and Part III.G of this permit).
Emergency Response and Public Notification Plan	The permittee must develop and implement an overflow emergency response and public notification plan. The permittee must submit written notice to EPA and IDEQ that the plan has been developed and implemented within 180 days of the effective date of this permit (See Part II.F of this permit).
List of Industrial Users	The permittee must develop and maintain a master list of the industrial users introducing pollutants to the POTW. The Permittee must submit this list, along with a summary description of the sources and information gathering methods used to develop this list, to EPA within two years following the effective date of this permit.

Table of Contents

Schedule of Submissions	2
I. Limitations and Monitoring Requirements	5
A. Discharge Authorization	5
B. Effluent Limitations and Monitoring	5
C. Surface Water Monitoring	8
II. Special Conditions	9
A. Operation and Maintenance Plan (O&M).....	9
B. Quality Assurance Plan (QAP)	10
C. Ammonia Schedule of Compliance	10
D. Facility Planning Requirement	12
E. Industrial Waste Management	13
F. Emergency Response and Public Notification Plan.....	14
III. Monitoring, Recording and Reporting Requirements	15
A. Representative Sampling (Routine and Non-Routine Discharges).....	15
B. Reporting of Monitoring Results	16
C. Monitoring Procedures.....	16
D. Additional Monitoring by Permittee	16
E. Records Contents	16
F. Retention of Records.....	16
G. Twenty-four Hour Notice of Noncompliance Reporting.....	17
H. Other Noncompliance Reporting	18
I. Public Notification	18
J. Notice of New Introduction of Toxic Pollutants.....	19
K. Compliance Schedules	19
IV. Compliance Responsibilities	19
A. Duty to Comply.....	19
B. Penalties for Violations of Permit Conditions	19
C. Need To Halt or Reduce Activity not a Defense	21
D. Duty to Mitigate.....	21
E. Proper Operation and Maintenance	21
F. Bypass of Treatment Facilities.....	21
G. Upset Conditions.....	22
H. Toxic Pollutants	23
I. Planned Changes.....	23
J. Anticipated Noncompliance.....	23
K. Reopener	23
V. General Provisions	24
A. Permit Actions	24

B. Duty to Reapply 24

C. Duty to Provide Information 24

D. Other Information 24

E. Signatory Requirements 24

F. Availability of Reports 25

G. Inspection and Entry 25

H. Property Rights 26

I. Transfers 26

J. State Laws 26

VI. Definitions 26

Appendix A 30

List of Tables

Table 1. Effluent Limitations and Monitoring Requirements 5

Table 2. Surface Water Monitoring Requirements 9

Table 3. Tasks Required Under the Schedule of Compliance for Ammonia 11

Table 4. Facility Design Criteria 12

I. Limitations and Monitoring Requirements

A. Discharge Authorization

During the effective period of this permit, the permittee is authorized to discharge pollutants from the outfall specified herein to Cow Creek, within the limits and subject to the conditions set forth herein. This permit authorizes the discharge of only those pollutants resulting from facility processes, waste streams, and operations that have been clearly identified in the permit application process.

B. Effluent Limitations and Monitoring

- The permittee must limit and monitor discharges from outfall 001 as specified in Table 1, *Effluent Limitations and Monitoring Requirements*, below. All figures represent maximum effluent limits unless otherwise indicated. The permittee must comply with the effluent limits in the tables at all times unless otherwise indicated, regardless of the frequency of monitoring or reporting required by other provisions of this permit.

Table 1. Effluent Limitations and Monitoring Requirements

Parameter	Units	Effluent Limitations			Monitoring Requirements		
		Average Monthly	Average Weekly	Maximum Daily	Sample Location	Sample Frequency	Sample Type
Parameters With Effluent Limits							
Biochemical Oxygen Demand (BOD ₅)	mg/L	30	45	--	Influent and Effluent	1/month	Grab
	lbs/day	38	56	--	Effluent		Calculation ¹
BOD ₅ Percent Removal	%	85 (minimum)	--	--	--	1/month	Calculation ²
Total Suspended Solids (TSS)	mg/L	45	65	--	Influent and Effluent	1/month	Grab
	lbs/day	56	81	--	Effluent		Calculation ¹
TSS Percent Removal	%	65 (minimum)	--	--	--	1/month	Calculation ²
<i>E. coli</i>	#/100 ml	126 ³	--	576 (instant. max) ⁴	Effluent	5/month	Grab
pH	std units	Between 6.5 – 9.0			Effluent	5/week ⁵	Grab
TRC ⁶	mg/L	0.007	--	0.018 ⁴	Effluent	1/week	Effluent
	lbs/day	0.01	--	0.02			Calculation ¹
Total Ammonia (as N) ⁷	mg/L	0.6	--	1.7 ⁴	Effluent	1/week	Grab
	lbs/day	0.8	--	2.1			Calculation ¹
Total Ammonia (as N) Interim Limit ⁷	mg/L	15	--	26 ⁴	Effluent	1/week	Grab
	lbs/day	19	--	33			Calculation ¹

Parameter	Units	Effluent Limitations			Monitoring Requirements		
		Average Monthly	Average Weekly	Maximum Daily	Sample Location	Sample Frequency	Sample Type
Total Phosphorus (as P) June 1 – Sept 30	lbs/day	2.0	4.1	--	Effluent	1/week	Calculation ¹
Seasonal Average Limit 0.6 kg/d							Calculation ⁸
Temperature ⁹	°C	--		22 Instantaneous Maximum and 19 Maximum Daily Average ¹⁰	Effluent	Continuous	Auto Record
Floating, Suspended, or Submerged Matter	--	See Paragraph I.B.4 of this permit				1/month	Visual Observation
Report Parameters							
Flow	mgd	Report	--	Report	Effluent	continuous	Meter
NPDES Application Form 2A (Part B.6) Effluent Testing Data ¹¹	--	--	--	--	Effluent	1/year	--
Notes							
<ol style="list-style-type: none"> Loading (in lbs/day) is calculated by multiplying the concentration (in mg/L) by the corresponding flow (in mgd) for the day of sampling and a conversion factor of 8.34. For more information on calculating, averaging, and reporting loads and concentrations see the <i>NPDES Self-Monitoring System User Guide</i> (EPA 833-B-85-100, March 1985). Percent Removal. The monthly average percent removal must be calculated from the arithmetic mean of the influent values and the arithmetic mean of the effluent values for that month using the following equation: (average monthly influent concentration – average monthly effluent concentration) ÷ average monthly influent concentration x 100. Influent and effluent samples must be taken over approximately the same time period. The average monthly <i>E. coli</i> bacteria counts must not exceed a geometric mean of 126/100 ml based on a minimum of five samples taken every 3 - 7 days within a calendar month. See Part VI of this permit for a definition of geometric mean. Reporting is required within 24 hours of a maximum daily limit or instantaneous maximum limit violation. See Paragraph I.B.5 and Part III.G of this permit. Samples must be taken on different days. The average monthly and maximum daily concentration limits for chlorine are not quantifiable using EPA approved test methods. The permittee will be in compliance with the average monthly and maximum daily effluent limits for chlorine provided the total chlorine residual level is at or below the compliance evaluation level of 0.05 mg/L, with an average monthly and maximum daily loading at or below 0.06 lbs/day (See Appendix A). Total Ammonia (as N) concentration and mass limits are effective on July 1, 2025. This date is at the end of an 8-year Compliance Schedule. See Section II.C for more information. Concentration and mass limits were derived from performance-based calculations (See Appendix D of the Fact Sheet). Until final concentration and mass limits are effective on July 1, 2025, an interim limit has been established. The interim limit is effective the first day of permit issuance. See Paragraph I.B.2 of the permit regarding average seasonal limit calculations. Temperature shall be measured using continuous measuring and recording devices such as probes or thermistors set at a minimum of one hour sampling intervals. See Paragraph I.B.3 for calculating maximum daily average. See NPDES Permit Application Form 2A, Part B.6 for the list of pollutants to be included in this testing. The Permittee must use sufficiently sensitive analytical methods in accordance with Appendix A of this permit. 							

2. Seasonal average limit for total phosphorus (phosphorus):
 - a) The seasonal average phosphorus load must not exceed 0.6 kg/day (1.3 lbs/day). The critical low flow period is June 1 through September 30.
 - b) The seasonal average phosphorus load must be calculated as the sum of all daily discharges (in lbs) calculated for phosphorus during the critical low flow season, divided by the number of days sampled for phosphorus during the critical low flow season.
 - c) The seasonal average phosphorus load must be reported on the November DMR.
3. Maximum daily average for temperature:
 - a) The maximum daily average for temperature must not exceed 19 degrees Celsius.
 - b) The maximum daily average for temperature must be calculated as the sum of all measurements for temperature collected during a 24-hour period, divided by the number of measurements collected during that 24-hour period.
 - c) Temperature data must be recorded using a micro-recording temperature devices known as thermistors. Set the recording device to record at one-hour intervals. Report the following temperature monitoring data on the DMR: monthly instantaneous maximum and maximum daily average.
 - d) Use the temperature device manufacturer's software to generate (export) an Excel or electronic ASCII text file. The file must be submitted annually to the EPA and IDEQ by January 31 for the previous monitoring year along with the placement log. The placement logs should include the following information for both thermistor deployment and retrieval: date, time, temperature device manufacturer ID, location, depth, whether it measured air or water temperature, and any other details that may explain data anomalies.
4. Narrative limitations for floating, suspended or submerged matter:
 - a) The permittee must not discharge floating, suspended, or submerged matter of any kind in concentrations causing nuisance or objectionable conditions or that may impair designated beneficial uses.
 - b) The permittee must observe the surface of the receiving water in the vicinity of where the effluent enters the surface water. The permittee must maintain a written log of the observation which includes the date, time, observer, and whether there is presence of floating, suspended or submerged matter. The log must be retained and made available to EPA or IDEQ upon request.
5. The permittee must report within 24 hours any violation of the maximum daily limits for the following pollutants: *E. coli*, TRC, and total ammonia as N (ammonia). Violations of all other effluent limits are to be reported at the time that discharge monitoring reports are submitted (See Parts III.B and III.G of this permit).

6. The permittee must collect effluent samples from the effluent stream after the last treatment unit prior to discharge into the receiving waters.
7. For all effluent monitoring, the permittee must use sufficiently sensitive analytical methods which meet the following:
 - a) Parameters with an effluent limit. The method must achieve a minimum level (ML) less than the effluent limitation unless otherwise specified in Table 1.
 - b) Parameters that do not have effluent limitations.
 - (i) The permittee must use a method that detects and quantifies the level of the pollutant, or
 - (ii) The permittee must use a method that can achieve a maximum ML less than or equal to those specified in Appendix A.
 - c) For parameters that do not have an effluent limit, the permittee may request different MLs. The request must be in writing and must be approved by EPA.
 - d) See also Part III.C *Monitoring Procedures*
8. For purposes of reporting on the DMR for a single sample, if a value is less than the MDL, the permittee must report “less than {numeric value of the MDL}” and if a value is less than the ML, the permittee must report “less than {numeric value of the ML}.”
9. For purposes of calculating monthly averages, zero may be assigned for values less than the MDL, and the {numeric value of the MDL} may be assigned for values between the MDL and the ML. If the average value is less than the MDL, the permittee must report “less than {numeric value of the MDL}” and if the average value is less than the ML, the permittee must report “less than {numeric value of the ML}.” If a value is equal to or greater than the ML, the permittee must report and use the actual value. The resulting average value must be compared to the compliance level, the ML, in assessing compliance.

C. Surface Water Monitoring

The permittee must conduct surface water monitoring. Surface water monitoring must start beginning on the effective date of the permit and continue until the expiration of the permit. The program must meet the following requirements:

1. Monitoring stations must be established in Cow Creek at the following locations:
 - a) Above the influence of the facility’s discharge (upstream).
2. To the extent practicable, surface water sample collection must occur on the same day as effluent sample collection.
3. The flow rate must be measured as near as practicable to the time that other ambient parameters are sampled.
4. Samples must be analyzed for the parameters listed in Table 2.
5. For all surface water monitoring, the permittee must use sufficiently sensitive analytical methods which meet the following:

- a) The method must detect and quantify the level of the pollutant, or
- b) The permittee must use a method that can achieve MLs less than or equal to those specified in Appendix A. The permittee may request different MLs. The request must be in writing and must be approved by EPA.

Table 2. Surface Water Monitoring Requirements

Parameter	Units	Frequency	Sample Type	Sample Location
Flow	cfs	1/quarter	Grab	Upstream
Dissolved Oxygen	mg/L	1/quarter	Grab	Upstream
Total Ammonia as N	mg/L	1/quarter	Grab	Upstream
Temperature	°C	1/quarter	Grab	Upstream
pH	standard units	1/quarter	Grab	Upstream

Notes:

1. For quarterly monitoring frequency, quarters are defined as: January 1 to March 31; April 1 to June 30; July 1 to September 30; and, October 1 to December 31.

6. Quality assurance/quality control (QA/QC) plans for all the monitoring must be documented in the Quality Assurance Plan required under Part II.B.
7. Submission of SW Monitoring
 - a) The permittee must submit all surface water monitoring results for the previous calendar year for all parameters in an annual report to EPA and IDEQ by January 31st of the following year and if applicable, with the application (see Part V.B of this permit, *Duty to Reapply*). The file must be in the format of one analytical result per row and include the following information: name and contact information of laboratory, sample identification number, sample location in latitude and longitude (decimal degrees format), method of location determination (i.e., GPS, survey etc.), date and time of sample collection, water quality parameter (or characteristic being measured), analysis result, result units, detection limit and definition (i.e., MDL etc.), analytical method, date completed, and any applicable notes.

II. Special Conditions

A. Operation and Maintenance Plan (O&M)

In addition to the requirements specified in Part IV.E, *Proper Operation and Maintenance*, within 180 days of the effective date of this permit, the permittee must submit written notice to EPA and IDEQ that an operations and maintenance (O&M) plan for the current wastewater treatment facility has been developed and implemented. The plan must be retained on site and made available to EPA and/or IDEQ upon request. Any changes occurring in the operation of the plant must be reflected within the O&M plan.

B. Quality Assurance Plan (QAP)

The permittee must develop a quality assurance plan (QAP) for all monitoring required by this permit. Within 180 days of the effective date of this permit, the permittee must submit written notice to EPA and IDEQ that the Plan has been developed and implemented. Any existing QAPs may be modified for compliance with this section.

1. The QAP must be designed to assist in planning for the collection and analysis of effluent and receiving water samples in support of the permit and in explaining data anomalies when they occur.
2. Throughout all sample collection and analysis activities, the permittee must use the EPA-approved QA/QC and chain-of-custody procedures described in *EPA Requirements for Quality Assurance Project Plans (EPA/QA/R-5)*¹ and *Guidance for Quality Assurance Project Plans (EPA/QA/G-5)*². The QAP must be prepared in the format that is specified in these documents.
3. At a minimum, the QAP must include the following:
 - a) Details on the number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements.
 - b) Map(s) indicating the location of each sampling point.
 - c) Qualification and training of personnel.
 - d) Name(s), address(es) and telephone number(s) of the laboratories used by or proposed to be used by the permittee.
4. The permittee must amend the QAP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAP.
5. Copies of the QAP must be retained on site and made available to EPA and/or IDEQ upon request.

C. Ammonia Schedule of Compliance

1. The permittee must achieve compliance with the ammonia limitations of Part I.B, Table 1. *Effluent Limitations and Monitoring Requirements*, by eight years from July 1, 2017.
2. Until compliance with the effluent limits is achieved, at a minimum, the permittee must complete the tasks and reports listed in Table 3.

¹<http://www.epa.gov/quality/qs-docs/r5-final.pdf>

² <http://www.epa.gov/quality/qs-docs/g5-final.pdf>

3. All deliverables listed under Table 3 must be submitted to IDEQ with copies of the deliverables sent to US EPA Region 10.

Original to: Idaho Department of Environmental Quality
Lewiston Regional Office
1118 "F" St.
Lewiston, ID 83501

Copy to: US EPA Region 10
Attn: NPDES Permits Unit
1200 Sixth Avenue, Suite 900
OWW-191
Seattle, Washington 98101-3140

Table 3. Tasks Required Under the Schedule of Compliance for Ammonia

Task No.	Due at End of Year(s)	Task Activity
1	2 years from Permit effective date (July 1, 2019)	<p>Facility Plan.</p> <p>The permittee must develop a facility plan that evaluates alternatives to meet the final effluent limitations for ammonia and select a preferred alternative.</p> <p>Deliverable: The permittee must provide written notice to EPA that the facility plan has been submitted to the IDEQ for the necessary approvals.</p>
2	3 years from Permit effective date (July 1, 2020)	<p>Preliminary Design.</p> <p>Deliverable: The permittee must submit the Preliminary Design to IDEQ for review and approval and notify EPA that the Preliminary Design was submitted.</p>
3	4 years from Permit effective date (July 1, 2021)	<p>Final Design.</p> <p>The permittee must complete design of the selected alternative for meeting the final ammonia effluent limitations.</p> <p>Deliverable: The permittee must submit the Final Design to IDEQ for review and approval and notify EPA that the Final Design was submitted.</p>
4	5 years from Permit effective date (July 1, 2022)	<p>Award Bid for Construction.</p> <p>Deliverable: The permittee must provide written notice to EPA and IDEQ that the bid award is complete. Notifications of construction progress should be sent in following years.</p> <p>Deliverable: The permittee must provide written notice to EPA and IDEQ that the bid award is complete.</p>
5	6 years from Permit effective date (July 1, 2023)	<p>Construction Complete.</p> <p>The permittee must complete construction to achieve the ammonia effluent limitations.</p> <p>Deliverable: The permittee must submit a construction completion report to the EPA and the IDEQ.</p>
6	8 years from Permit effective date (July 1, 2025)	<p>Meet Effluent Limitation for Ammonia.</p> <p>Construction and optimization of process such that compliance with the ammonia effluent limitations are achieved.</p> <p>Deliverable: The permittee must provide written notice to the EPA and the IDEQ that the ammonia effluent limitations are achieved.</p>

Task No.	Due at End of Year(s)	Task Activity
Footnotes:		
If compliance with the final ammonia effluent limits is achieved sooner than the listed deadlines, the permittee may submit the supporting documentation earlier than the dates listed above. The permittee must provide written notice to the EPA and the IDEQ that the ammonia effluent limitations are achieved.		

4. The permittee must submit an Annual Report of Progress which outlines the progress made towards reaching the compliance date for the ammonia effluent limitations. The annual Report of Progress must be submitted by July 20th of each year. The first report is due July 20th, 2018 and annually thereafter, until compliance with the ammonia effluent limits is achieved. See also Part III.K, *Compliance Schedules*. At a minimum, the annual report must include:
 - a) An assessment of the previous year of ammonia data and comparison to the effluent limitations.
 - b) A report on progress made towards meeting the effluent limitations.
 - c) Further actions and milestones targeted for the upcoming year.

D. Facility Planning Requirement

1. Design Criteria. The design flows and waste loads for the permitted facility are:

Table 4. Facility Design Criteria

Facility Design Criteria	Value	Units
Facility Design Flow	0.15	mgd
Maximum Monthly Effluent BOD ₅ Loading	38	lbs/day
Maximum Monthly Effluent TSS Loading	56	lbs/day
Maximum monthly loading means the largest loading anticipated to occur during a continuous 30-day period, expressed as a daily average (for BOD ₅ or TSS).		

2. Plan for maintaining adequate capacity
 - a) Condition to trigger plan development
 - (i) Each month, the Permittee must record the average daily flow, BOD₅ loading, and TSS loading entering the facility for that month.
 - (ii) When the actual flow or waste loads for three consecutive months during a 12-month period exceed 85% of the facility planning values listed in Table 4, the permittee must develop a new or updated plan and schedule for continuing to maintain capacity and maintain compliance with effluent limits.
 - b) Submittal. The plan must be made available to the EPA, IDEQ or authorized representative upon request.

- c) Plan and schedule content. The plan and schedule must identify the actions necessary to maintain adequate capacity and to meet the limits and requirements of the permit. The Permittee must consider the following topics and actions in its plan:
- (i) Analysis of the present design and proposed process modifications.
 - (ii) Reduction or elimination of excessive infiltration and inflow of uncontaminated ground and surface water into the sewer system.
 - (iii) Limits on future sewer extensions or connections or additional waste loads.
 - (iv) Modification or expansion of facilities.
 - (v) Reduction of industrial or commercial flows or waste loads.

E. Industrial Waste Management

1. The Permittee must not authorize the introduction of pollutants that would inhibit, interfere, or otherwise be incompatible with operation of the treatment works including interference with the use or disposal of municipal sludge.
2. The Permittee must not authorize, under any circumstances, the introduction of the following pollutants to the POTW from any source of nondomestic discharge:
 - a) Any pollutant which may cause Pass Through or Interference;
 - b) Pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, waste streams with a closed cup flashpoint of less than 60° C (140° F) using the test methods specified in 40 CFR 261.21;
 - c) Pollutants which will cause corrosive structural damage to the POTW, but in no case indirect discharges with a pH of lower than 5.0 s.u., unless the treatment facilities are specifically designed to accommodate such indirect discharges;
 - d) Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, or other interference with the operation of the POTW;
 - e) Any pollutant, including oxygen demanding pollutants (e.g., BOD₅), released in an indirect discharge at a flow rate and/or pollutant concentration which will cause Interference with any treatment process at the POTW;
 - f) Heat in amounts which will inhibit biological activity in the POTW resulting in Interference, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40° C (104° F) unless the Approval Authority, upon request of the POTW, approves alternate temperature limits;
 - g) Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through at the POTW;
 - h) Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;

- i) Any trucked or hauled pollutants, except at discharge points designated by the POTW
 - j) Any specific pollutant which exceeds a local limitation established by the Permittee in accordance with the requirements of 40 CFR 403.5(c) and (d).
3. The Permittee must develop and maintain a master list of the industrial users introducing pollutants to the POTW. Industrial user means any source of indirect discharge from a non-domestic source. This list must identify:
- a) Names and addresses of all industrial users;
 - b) Which industrial users are significant industrial users (SIUs) (see Paragraph 5 of this Part);
 - c) Which SIUs are subject to categorical Pretreatment Standards (see 40 CFR 405-471);
 - d) Which standards are applicable to each industrial user (if any);
 - e) Which industrial users are subject to local standards that are more stringent than the categorical Pretreatment Standards; and
 - f) Which industrial users are subject only to local requirements.
4. The Permittee must submit this list, along with a summary description of the sources and information gathering methods used to develop this list, to EPA within two years following the effective date of the NPDES permit.
5. For the purposes of this list development, the term SIU means:
- a) All industrial users subject to Categorical Pretreatment Standards under 40 CFR 403.6 and 40 CFR chapter I, subchapter N; and
 - b) Any other industrial user that:
 - (i) discharges an average of 25,000 gallons per day or more of process wastewater to the POTW (excluding sanitary, noncontact cooling and boiler blowdown wastewater);
 - (ii) contributes a process waste stream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or
 - (iii) is designated as such by EPA or the Permittee on the basis that the industrial user has a reasonable potential for adversely affecting the POTW's operation or for violation any Pretreatment Standard or requirement in accordance with 40 CFR 403.8(f)(6).Permit Writer: The following language requiring the permittee to develop a municipal code is required if a SIU discharges to the POTW. In addition, there are other situations where you may consider including this language.

F. Emergency Response and Public Notification Plan

1. The permittee must develop and implement an overflow emergency response and public notification plan that identifies measures to protect public health from

overflows that may endanger health and unanticipated bypasses or upsets that exceed any effluent limitation in the permit. At a minimum the plan must include mechanisms to:

- a) Ensure that the permittee is aware (to the greatest extent possible) of all overflows from portions of the collection system over which the permittee has ownership or operational control and unanticipated bypass or upset that exceed any effluent limitation in the permit;
 - b) Ensure appropriate responses including assurance that reports of an overflow or of an unanticipated bypass or upset that exceed any effluent limitation in the permit are immediately dispatched to appropriate personnel for investigation and response;
 - c) Ensure immediate notification to the public, health agencies, and other affected public entities (including public water systems). The overflow response plan must identify the public health and other officials who will receive immediate notification;
 - d) Ensure that appropriate personnel are aware of and follow the plan and are appropriately trained; and
 - e) Provide emergency operations.
2. The permittee must submit written notice to EPA and IDEQ that the plan has been developed and implemented within 180 days of the effective date of this permit. Any existing emergency response and public notification plan may be modified for compliance with this section.

III. Monitoring, Recording and Reporting Requirements

A. Representative Sampling (Routine and Non-Routine Discharges)

Samples and measurements must be representative of the volume and nature of the monitored discharge.

In order to ensure that the effluent limits set forth in this permit are not violated at times other than when routine samples are taken, the permittee must collect additional samples at the appropriate outfall whenever any discharge occurs that may reasonably be expected to cause or contribute to a violation that is unlikely to be detected by a routine sample.

The permittee must analyze the additional samples for those parameters limited in Part I.B of this permit that are likely to be affected by the discharge.

The permittee must collect such additional samples as soon as the spill, discharge, or bypassed effluent reaches the outfall. The samples must be analyzed in accordance with Part III.C of this permit, *Monitoring Procedures*. The permittee must report all additional monitoring in accordance with Part III.D of this permit, *Additional Monitoring by Permittee*.

B. Reporting of Monitoring Results

The permittee must submit monitoring data and other reports electronically using NetDMR.

1. Monitoring data must be submitted electronically to EPA no later than the 20th of the month following the completed reporting period. All reports required under this permit must be submitted to EPA as a legible electronic attachment to the DMR.
2. The permittee must sign and certify all DMRs, and all other reports, in accordance with the requirements of Part V.E, of this permit Signatory Requirements.
3. The permittee must submit copies of the DMRs and other reports to IDEQ.
4. The permittee may use NetDMR after requesting and receiving permission from US EPA Region 10. NetDMR is accessed from:
<https://netdmr.epa.gov/netdmr/public/home.htm>

C. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR 136, unless another method is required under 40 CFR subchapters N or O, or other test procedures have been specified in this permit or approved by EPA as an alternate test procedure under 40 CFR 136.5.

D. Additional Monitoring by Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR 136 or as specified in this permit, the permittee must include the results of this monitoring in the calculation and reporting of the data submitted in the DMR.

Upon request by EPA, the permittee must submit results of any other sampling, regardless of the test method used.

E. Records Contents

Records of monitoring information must include:

1. the date, exact place, and time of sampling or measurements;
2. the name(s) of the individual(s) who performed the sampling or measurements;
3. the date(s) analyses were performed;
4. the names of the individual(s) who performed the analyses;
5. the analytical techniques or methods used; and
6. the results of such analyses.

F. Retention of Records

The permittee must retain records of all monitoring information, including, all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit,

copies of DMRs, a copy of the NPDES permit, and records of all data used to complete the application for this permit, for a period of at least five years from the date of the sample, measurement, report or application. This period may be extended by request of EPA or IDEQ at any time.

G. Twenty-four Hour Notice of Noncompliance Reporting

1. The permittee must report the following occurrences of noncompliance by telephone within 24 hours from the time the permittee becomes aware of the circumstances:
 - a) any noncompliance that may endanger health or the environment;
 - b) any unanticipated bypass that exceeds any effluent limitation in the permit (See Part IV.F of this permit, *Bypass of Treatment Facilities*);
 - c) any upset that exceeds any effluent limitation in the permit (See Part IV.G of this permit, *Upset Conditions*); or
 - d) any violation of a maximum daily discharge limitation for applicable pollutants identified by Part I.B.5. of this permit.
 - e) any overflow prior to the treatment works over which the permittee has ownership or has operational control. An overflow is any spill, release or diversion of municipal sewage including:
 - (i) an overflow that results in a discharge to waters of the United States; and
 - (ii) an overflow of wastewater, including a wastewater backup into a building (other than a backup caused solely by a blockage or other malfunction in a privately owned sewer or building lateral) that does not reach waters of the United States.
2. The permittee must also provide a written submission within five days of the time that the permittee becomes aware of any event required to be reported under Paragraph 1 above. The written submission must contain:
 - a) a description of the noncompliance and its cause;
 - b) the period of noncompliance, including exact dates and times;
 - c) the estimated time noncompliance is expected to continue if it has not been corrected; and
 - d) steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
 - e) if the noncompliance involves an overflow, the written submission must contain:
 - (i) The location of the overflow;
 - (ii) The receiving water (if there is one);
 - (iii) An estimate of the volume of the overflow;

- (iv) A description of the sewer system component from which the release occurred (e.g., manhole, constructed overflow pipe, crack in pipe);
 - (v) The estimated date and time when the overflow began and stopped or will be stopped;
 - (vi) The cause or suspected cause of the overflow;
 - (vii) Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
 - (viii) An estimate of the number of persons who came into contact with wastewater from the overflow; and
 - (ix) Steps taken or planned to mitigate the impact(s) of the overflow and a schedule of major milestones for those steps.
3. The Director of the Office of Compliance and Enforcement may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the NPDES Compliance Hotline in Seattle, Washington, by telephone, (206) 553-1846.
1. Reports must be submitted in paper form. The permittee must sign and certify the report in accordance with the requirements of Part V.E, of this permit *Signatory Requirements*. The permittee must submit the legible originals of these documents to the Director, Office of Compliance and Enforcement, with copies to IDEQ at the following addresses:

Original to: US EPA Region 10
Attn: ICIS Data Entry Team
1200 Sixth Avenue, Suite 900
OCE-101
Seattle, Washington 98101-3140

Copy to: Idaho Department of Environmental Quality
Lewiston Regional Office
1118 "F" St.
Lewiston, ID 83501

H. Other Noncompliance Reporting

The permittee must report all instances of noncompliance, not required to be reported within 24 hours, at the time that monitoring reports for Part III.B of this permit, *Reporting of Monitoring Results* are submitted. The reports must contain the information listed in Paragraph III.G.2 of this permit.

I. Public Notification

The permittee must immediately notify the public, health agencies and other affected entities (e.g., public water systems) of any overflow which the permittee owns or has operational control; or any unanticipated bypass or upset that exceeds any effluent

limitation in the permit in accordance with the notification procedures developed in accordance with Part II.F of this permit.

J. Notice of New Introduction of Toxic Pollutants

The permittee must notify the Director of the Office of Water and Watersheds and IDEQ in writing of:

1. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to Sections 301 or 306 of the Act if it were directly discharging those pollutants; and
2. Any substantial change in the volume or character of pollutants being introduced into the POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
3. For the purposes of this section, adequate notice must include information on:
 - a) The quality and quantity of effluent to be introduced into the POTW, and
 - b) Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
4. The permittee must notify the Director of the Office of Water and Watersheds at the following address:

US EPA Region 10
Attn: NPDES Permits Unit Manager
1200 6th Avenue
Suite 900 OWW-191
Seattle, WA 98101-3140

K. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date.

IV. Compliance Responsibilities

A. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification, or for denial of a permit renewal application.

B. Penalties for Violations of Permit Conditions

1. Civil and Administrative Penalties. Pursuant to 40 CFR Part 19 and the Act, any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil

penalty not to exceed the maximum amounts authorized by Section 309(d) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 USC § 2461 note) as amended by the Debt Collection Improvement Act (31 USC § 3701 note) (currently \$37,500 per day for each violation).

2. **Administrative Penalties.** Any person may be assessed an administrative penalty by the Administrator for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Pursuant to 40 CFR Part 19 and the Act, administrative penalties for Class I violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(A) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 USC § 2461 note) as amended by the Debt Collection Improvement Act (31 USC § 3701 note) (currently \$16,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$37,500). Pursuant to 40 CFR Part 19 and the Act, penalties for Class II violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(B) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 USC § 2461 note) as amended by the Debt Collection Improvement Act (31 USC § 3701 note) (currently \$16,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$187,500).
3. **Criminal Penalties:**
 - a) **Negligent Violations.** The Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.
 - b) **Knowing Violations.** Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.
 - c) **Knowing Endangerment.** Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of

not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the Act, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

- d) False Statements. The Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. The Act further provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

C. Need To Halt or Reduce Activity not a Defense

It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with this permit.

D. Duty to Mitigate

The permittee must take all reasonable steps to minimize or prevent any discharge in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

E. Proper Operation and Maintenance

The permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

F. Bypass of Treatment Facilities

1. Bypass not exceeding limitations. The permittee may allow any bypass to occur that does not cause effluent limitations to be exceeded, but only if it also is for

essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Paragraphs 2 and 3 of this Part.

2. Notice.
 - a) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it must submit prior written notice, if possible at least 10 days before the date of the bypass.
 - b) Unanticipated bypass. The permittee must submit notice of an unanticipated bypass as required under Part III.G of this permit, *Twenty-four Hour Notice of Noncompliance Reporting*.
3. Prohibition of bypass.
 - a) Bypass is prohibited, and the Director of the Office of Compliance and Enforcement may take enforcement action against the permittee for a bypass, unless:
 - (i) The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance; and
 - (iii) The permittee submitted notices as required under Paragraph 2 of this Part.
 - b) The Director of the Office of Compliance and Enforcement may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Paragraph 3.a. of this Part.

G. Upset Conditions

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the permittee meets the requirements of Paragraph 2 of this Part. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
2. Conditions necessary for a demonstration of upset. To establish the affirmative defense of upset, the permittee must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - a) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - b) The permitted facility was at the time being properly operated;

- c) The permittee submitted notice of the upset as required under Part III.G of this permit, *Twenty-four Hour Notice of Noncompliance Reporting* and
 - d) The permittee complied with any remedial measures required under Part IV.D of this permit, *Duty to Mitigate*.
3. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

H. Toxic Pollutants

The permittee must comply with effluent standards or prohibitions established under Section 307(a) and with standards for sewage sludge use or disposal established under section 405(d) of the Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

I. Planned Changes

The permittee must give written notice to the Director of the Office of Water and Watersheds as specified in Paragraph III.J.4 of this permit, and IDEQ as soon as possible of any planned physical alterations or additions to the permitted facility whenever:

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as determined in 40 CFR 122.29(b); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this permit.
3. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application site.

J. Anticipated Noncompliance

The permittee must give written advance notice to the Director of the Office of Compliance and Enforcement (EPA) and IDEQ of any planned changes in the permitted facility or activity that may result in noncompliance with this permit.

K. Reopener

This permit may be reopened to include any applicable standard for sewage sludge use or disposal promulgated under section 405(d) of the Act. The Director may modify or revoke and reissue the permit if the standard for sewage sludge use or disposal is more stringent than any requirements for sludge use or disposal in the permit, or controls a pollutant or practice not limited in the permit.

V. General Provisions

A. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause as specified in 40 CFR 122.62, 122.64, or 124.5. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

B. Duty to Reapply

If the permittee intends to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. In accordance with 40 CFR 122.21(d), and unless permission for the application to be submitted at a later date has been granted by the Regional Administrator, the permittee must submit a new application at least 180 days before the expiration date of this permit.

C. Duty to Provide Information

The permittee must furnish to EPA and IDEQ, within the time specified in the request, any information that EPA or IDEQ may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee must also furnish to EPA or IDEQ, upon request, copies of records required to be kept by this permit.

D. Other Information

When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or that it submitted incorrect information in a permit application or any report to EPA or IDEQ, it must promptly submit the omitted facts or corrected information in writing.

E. Signatory Requirements

All applications, reports or information submitted to EPA and IDEQ must be signed and certified as follows.

1. All permit applications must be signed as follows:
 - a) For a corporation: by a responsible corporate officer.
 - b) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively.
 - c) For a municipality, state, federal, Indian tribe, or other public agency: by either a principal executive officer or ranking elected official.
2. All reports required by the permit and other information requested by EPA or IDEQ must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a) The authorization is made in writing by a person described above;

- b) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company; and
 - c) The written authorization is submitted to the Director of the Office of Compliance and Enforcement and IDEQ.
3. Changes to authorization. If an authorization under Paragraph 2 of this Part is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Paragraph 2 of this Part must be submitted to the Director of the Office of Compliance and Enforcement and IDEQ prior to or together with any reports, information, or applications to be signed by an authorized representative.
4. Certification. Any person signing a document under this Part must make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

F. Availability of Reports

In accordance with 40 CFR Part 2, information submitted to EPA pursuant to this permit may be claimed as confidential by the permittee. In accordance with the Act, permit applications, permits and effluent data are not considered confidential. Any confidentiality claim must be asserted at the time of submission by stamping the words “confidential business information” on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice to the permittee. If a claim is asserted, the information will be treated in accordance with the procedures in 40 CFR 2, Subpart B (Public Information) and 41 Fed. Reg. 36902 through 36924 (September 1, 1976), as amended.

G. Inspection and Entry

The permittee must allow the Director of the Office of Compliance and Enforcement, EPA Region 10; IDEQ; or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location.

H. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any injury to persons or property or invasion of other private rights, nor any infringement of federal, tribal, state or local laws or regulations.

I. Transfers

This permit is not transferable to any person except after written notice to the Director of the Office of Water and Watersheds as specified in Part III.J.4. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act. (*See* 40 CFR 122.61; in some cases, modification or revocation and reissuance is mandatory).

J. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Act.

VI. Definitions

1. "Act" means the Clean Water Act.
2. "Approval Authority" means the Administrator of the EPA, or an authorized representative.
3. "Average monthly discharge limitation" means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month.
4. "Average weekly discharge limitation" means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily

discharges” measured during a calendar week divided by the number of “daily discharges” measured during that week.

5. “Best Management Practices” (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the United States. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage areas.
6. “Bypass” means the intentional diversion of waste streams from any portion of a treatment facility.
7. “Composite” - see “24-hour composite”.
8. “Daily discharge” means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the “daily discharge” is calculated as the average measurement of the pollutant over the day.
9. “Director of the Office of Compliance and Enforcement” means the Director of the Office of Compliance and Enforcement, EPA Region 10, or an authorized representative.
10. “Director of the Office of Water and Watersheds” means the Director of the Office of Water and Watersheds, EPA Region 10, or an authorized representative.
11. “DMR” means discharge monitoring report.
12. “EPA” means the United States Environmental Protection Agency.
13. “Geometric Mean” means the n^{th} root of a product of n factors, or the antilogarithm of the arithmetic mean of the logarithms of the individual sample values.
14. “Grab” sample is an individual sample collected over a period of time not exceeding 15 minutes.
15. “IDEQ” means the Idaho Department of Environmental Quality.
16. “Indirect Discharge” means the introduction of pollutants into a POTW from any non-domestic source regulated under section 307(b), (c) or (d) of the Act.
17. “Industrial User” means a source of “Indirect Discharge.”
18. “Interference” means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both: 1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and 2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following

statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

19. "Maximum daily discharge limitation" means the highest allowable "daily discharge."
20. "Method Detection Limit (MDL)" means the minimum concentration of a substance (analyte) that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero and is determined from analysis of a sample in a given matrix containing the analyte.
21. "Minimum Level (ML)" means either the sample concentration equivalent to the lowest calibration point in a method or a multiple of the method detection limit (MDL). Minimum levels may be obtained in several ways: They may be published in a method; they may be sample concentrations equivalent to the lowest acceptable calibration point used by a laboratory; or they may be calculated by multiplying the MDL in a method, or the MDL determined by a lab, by a factor.
22. "National Pollutant Discharge Elimination System (NPDES)" means, the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and enforcing pretreatment requirements, under sections 307, 402, 318, and 405 of the Act.
23. "Pass Through" means a Discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).
24. "QA/QC" means quality assurance/quality control.
25. "Regional Administrator" means the Regional Administrator of Region 10 of the EPA, or the authorized representative of the Regional Administrator.
26. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
27. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

28. "24-hour composite" sample means a combination of at least 8 discrete sample aliquots of at least 100 milliliters, collected over periodic intervals from the same location, during the operating hours of a facility over a 24 hour period. The composite must be flow proportional. The sample aliquots must be collected and stored in accordance with procedures prescribed in the most recent edition of Standard Methods for the Examination of Water and Wastewater.

Appendix A

Minimum Levels

The Table below lists the maximum Minimum Level (ML) for pollutants that may have monitoring requirements in the permit. The permittee may request different MLs. The request must be in writing and must be approved by EPA. If the Permittee is unable to obtain the required ML in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection limit (MDL) and a ML to EPA with appropriate laboratory documentation.

CONVENTIONAL PARAMETERS

Pollutant & CAS No. (if available)	Minimum Level (ML) $\mu\text{g/L}$ unless specified
Biochemical Oxygen Demand	2 mg/L
Soluble Biochemical Oxygen Demand	2 mg/L
Chemical Oxygen Demand	10 mg/L
Dissolved Organic Carbon	1 mg/L
Total Organic Carbon	1 mg/L
Total Suspended Solids	5 mg/L
Total Ammonia (as N)	50
Dissolved oxygen	+/- 0.2 mg/L
Temperature	+/- 0.2° C
pH	N/A

NONCONVENTIONAL PARAMETERS

Pollutant & CAS No. (if available)	Minimum Level (ML) $\mu\text{g/L}$ unless specified
Total Alkalinity	5 mg/L as CaCO_3
Chlorine, Total Residual	50.0
Color	10 color units
Fluoride (16984-48-8)	100
Nitrate + Nitrite Nitrogen (as N)	100
Nitrogen, Total Kjeldahl (as N)	300
Soluble Reactive Phosphorus (as P)	10
Phosphorus, Total (as P)	10
Oil and Grease (HEM) (Hexane Extractable Material)	5,000
Salinity	3 practical salinity units or scale (PSU or PSS)
Settleable Solids	500 (or 0.1 mL/L)
Sulfate (as mg/L SO_4)	0.2 mg/L
Sulfide (as mg/L S)	0.2 mg/L

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
Sulfite (as mg/L SO ₃)	2 mg/L
Total dissolved solids	20 mg/L
Total Hardness	200 as CaCO ₃
Aluminum, Total (7429-90-5)	10
Barium Total (7440-39-3)	2.0
BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes)	2
Boron Total (7440-42-8)	10.0
Cobalt, Total (7440-48-4)	0.25
Iron, Total (7439-89-6)	50
Magnesium, Total (7439-95-4)	50
Molybdenum, Total (7439-98-7)	0.5
Manganese, Total (7439-96-5)	0.5
Tin, Total (7440-31-5)	1.5
Titanium, Total (7440-32-6)	2.5

PRIORITY POLLUTANTS

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
METALS, CYANIDE & TOTAL PHENOLS	
Antimony, Total (7440-36-0)	1.0
Arsenic, Total (7440-38-2)	0.5
Beryllium, Total (7440-41-7)	0.5
Cadmium, Total (7440-43-9)	0.1
Chromium (hex) dissolved (18540-29-9)	1.2
Chromium, Total (7440-47-3)	1.0
Copper, Total (7440-50-8)	2.0
Lead, Total (7439-92-1)	0.16
Mercury, Total (7439-97-6)	0.0005
Nickel, Total (7440-02-0)	0.5
Selenium, Total (7782-49-2)	1.0
Silver, Total (7440-22-4)	0.2
Thallium, Total (7440-28-0)	0.36
Zinc, Total (7440-66-6)	2.5
Cyanide, Total (57-12-5)	10
Cyanide, Weak Acid Dissociable	10
Cyanide, Free Amenable to Chlorination (Available Cyanide)	10
Phenols, Total	50

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
2-Chlorophenol (95-57-8)	2.0
2,4-Dichlorophenol (120-83-2)	1.0
2,4-Dimethylphenol (105-67-9)	1.0
4,6-dinitro-o-cresol (534-52-1) (2-methyl-4,6,-dinitrophenol)	2.0
2,4 dinitrophenol (51-28-5)	2.0
2-Nitrophenol (88-75-5)	1.0
4-nitrophenol (100-02-7)	1.0
Parachlorometa cresol (59-50-7) (4-chloro-3-methylphenol)	2.0
Pentachlorophenol (87-86-5)	1.0
Phenol (108-95-2)	4.0
2,4,6-Trichlorophenol (88-06-2)	4.0
VOLATILE COMPOUNDS	
Acrolein (107-02-8)	10
Acrylonitrile (107-13-1)	2.0
Benzene (71-43-2)	2.0
Bromoform (75-25-2)	2.0
Carbon tetrachloride (56-23-5)	2.0
Chlorobenzene (108-90-7)	2.0
Chloroethane (75-00-3)	2.0
2-Chloroethylvinyl Ether (110-75-8)	2.0
Chloroform (67-66-3)	2.0
Dibromochloromethane (124-48-1)	2.0
1,2-Dichlorobenzene (95-50-1)	7.6
1,3-Dichlorobenzene (541-73-1)	7.6
1,4-Dichlorobenzene (106-46-7)	17.6
Dichlorobromomethane (75-27-4)	2.0
1,1-Dichloroethane (75-34-3)	2.0
1,2-Dichloroethane (107-06-2)	2.0
1,1-Dichloroethylene (75-35-4)	2.0
1,2-Dichloropropane (78-87-5)	2.0
1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene) (542-75-6) 6	2.0
Ethylbenzene (100-41-4)	2.0

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
Methyl bromide (74-83-9) (Bromomethane)	10.0
Methyl chloride (74-87-3) (Chloromethane)	2.0
Methylene chloride (75-09-2)	10.0
1,1,2,2-Tetrachloroethane (79-34-5)	2.0
Tetrachloroethylene (127-18-4)	2.0
Toluene (108-88-3)	2.0
1,2-Trans-Dichloroethylene (156-60-5) (Ethylene dichloride)	2.0
1,1,1-Trichloroethane (71-55-6)	2.0
1,1,2-Trichloroethane (79-00-5)	2.0
Trichloroethylene (79-01-6)	2.0
Vinyl chloride (75-01-4)	2.0
BASE/NEUTRAL COMPOUNDS	
Acenaphthene (83-32-9)	0.4
Acenaphthylene (208-96-8)	0.6
Anthracene (120-12-7)	0.6
Benzidine (92-87-5)	24
Benzyl butyl phthalate (85-68-7)	0.6
Benzo(a)anthracene (56-55-3)	0.6
Benzo(b)fluoranthene (3,4-benzofluoranthene) (205-99-2) 7	1.6
Benzo(j)fluoranthene (205-82-3) 7	1.0
Benzo(k)fluoranthene (11,12-benzofluoranthene) (207-08-9) 7	1.6
Benzo(r,s,t)pentaphene (189-55-9)	1.0
Benzo(a)pyrene (50-32-8)	1.0
Benzo(ghi)Perylene (191-24-2)	1.0
Bis(2-chloroethoxy)methane (111-91-1)	21.2
Bis(2-chloroethyl)ether (111-44-4)	1.0
Bis(2-chloroisopropyl)ether (39638-32-9)	0.6
Bis(2-ethylhexyl)phthalate (117-81-7)	0.5
4-Bromophenyl phenyl ether (101-55-3)	0.4
2-Chloronaphthalene (91-58-7)	0.6
4-Chlorophenyl phenyl ether (7005-72-3)	0.5

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
Chrysene (218-01-9)	0.6
Dibenzo (a,h)acridine (226-36-8)	10.0
Dibenzo (a,j)acridine (224-42-0)	10.0
Dibenzo(a-h)anthracene (53-70-3)(1,2,5,6-dibenzanthracene)	1.6
Dibenzo(a,e)pyrene (192-65-4)	10.0
Dibenzo(a,h)pyrene (189-64-0)	10.0
3,3-Dichlorobenzidine (91-94-1)	1.0
Diethyl phthalate (84-66-2)	7.6
Dimethyl phthalate (131-11-3)	6.4
Di-n-butyl phthalate (84-74-2)	1.0
2,4-dinitrotoluene (121-14-2)	0.4
2,6-dinitrotoluene (606-20-2)	0.4
Di-n-octyl phthalate (117-84-0)	0.6
1,2-Diphenylhydrazine (as Azobenzene) (122-66-7)	20
Fluoranthene (206-44-0)	0.6
Fluorene (86-73-7)	0.6
Hexachlorobenzene (118-74-1)	0.6
Hexachlorobutadiene (87-68-3)	1.0
Hexachlorocyclopentadiene (77-47-4)	1.0
Hexachloroethane (67-72-1)	1.0
Indeno(1,2,3-cd)Pyrene (193-39-5)	1.0
Isophorone (78-59-1)	1.0
3-Methyl cholanthrene (56-49-5)	8.0
Naphthalene (91-20-3)	0.6
Nitrobenzene (98-95-3)	1.0
N-Nitrosodimethylamine (62-75-9)	4.0
N-Nitrosodi-n-propylamine (621-64-7)	1.0
N-Nitrosodiphenylamine (86-30-6)	1.0
Perylene (198-55-0)	7.6
Phenanthrene (85-01-8)	0.6
Pyrene (129-00-0)	0.6
1,2,4-Trichlorobenzene (120-82-1)	0.6

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
DIOXIN	
2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (176-40-16) (2,3,7,8 TCDD)	5 µg/L
PESTICIDES/PCBs	
Aldrin (309-00-2)	0.05
alpha-BHC (319-84-6)	0.05
beta-BHC (319-85-7)	0.05
gamma-BHC (58-89-9)	0.05
delta-BHC (319-86-8)	0.05
Chlordane (57-74-9)	0.05
4,4'-DDT (50-29-3)	0.05
4,4'-DDE (72-55-9)	0.05
4,4' DDD (72-54-8)	0.05
Dieldrin (60-57-1)	0.05
alpha-Endosulfan (959-98-8)	0.05
beta-Endosulfan (33213-65-9)	0.05
Endosulfan Sulfate (1031-07-8)	0.05
Endrin (72-20-8)	0.05
Endrin Aldehyde (7421-93-4)	0.05
Heptachlor (76-44-8)	0.05
Heptachlor Epoxide (1024-57-3)	0.05
PCB-1242 (53469-21-9)	0.5
PCB-1254 (11097-69-1)	0.5
PCB-1221 (11104-28-2)	0.5
PCB-1232 (11141-16-5)	0.5
PCB-1248 (12672-29-6)	0.5
PCB-1260 (11096-82-5)	0.5
PCB-1016 (12674-11-2)	0.5
Toxaphene (8001-35-2)	0.5