

United States Environmental Protection Agency  
 Region 10  
 1200 Sixth Avenue Suite 900  
 Seattle, Washington 98101

### **Authorization to Discharge Under the National Pollutant Discharge Elimination System**

In compliance with the provisions of the Clean Water Act, 33 U.S.C. §1251 *et seq.*, as amended by the Water Quality Act of 1987, P.L. 100-4, the "Act",

#### **City of Kuna Wastewater Treatment Plant**

is authorized to discharge from the wastewater treatment plant located in Kuna, Idaho, at the following location(s):

<b>Outfall</b>	<b>Receiving Water</b>	<b>Latitude</b>	<b>Longitude</b>
001	Indian Creek	43° 32' 51"	116° 29' 37"

in accordance with discharge point(s), effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective June 1, 2009

This permit and the authorization to discharge shall expire at midnight, May 31, 2014.

The permittee shall reapply for a permit reissuance on or before, 180 days before the expiration of this permit if the permittee intends to continue operations and discharges at the facility beyond the term of this permit.

Signed this 21<sup>st</sup> day of April, 2009

/s/  
 \_\_\_\_\_  
 Michael A. Bussell, Director  
 Office of Water and Watersheds

## Schedule of Submissions

The following is a summary of some of the items the permittee must complete and/or submit to EPA during the term of this permit:

<b>Item</b>	<b>Due Date</b>
1. Discharge Monitoring Reports (DMR)	DMRs are due monthly and must be postmarked on or before the 20th day of the month following the monitoring month (see III.B).
2. Quality Assurance Plan (QAP)	The permittee must provide EPA and IDEQ with written notification that the Plan has been developed and implemented by the effective date of the final permit (see II.B). The Plan must be kept on site and made available to EPA and IDEQ upon request.
3. Operation and Maintenance (O&M) Plan	The permittee must provide EPA and IDEQ with written notification that the Plan has been developed and implemented by the effective date of the final permit (see II.A). The Plan must be kept on site and made available to EPA and IDEQ upon request.
4. NPDES Application Renewal	The application must be submitted at least 180 days before the expiration date of the permit (see V.B).
5. Surface Water Monitoring Report	The Report must be submitted with the next permit application. Additionally, the permittee must submit annual certification that monitoring has been conducted in accordance with all conditions in this Permit (see comment on Part I.C).
6. Twenty-Four Hour Notice of Noncompliance Reporting	The permittee must report certain occurrences of noncompliance by telephone within 24 hours from the time the permittee becomes aware of the circumstances. (See I.B.2 and III.G)
7. Phosphorus Offset Plan	Prior to discharging more than 1.1 lb/day of total phosphorus on a monthly average basis or more than 1.65 lb/day of total phosphorus on a weekly average basis during the season of May 1st through September 30th, the permittee must submit written notice to EPA that it has developed and obtained IDEQ approval of a plan that describes how the City will comply with IDAPA 58.01.02.054.04 (See Part I.B.2).

## Table of Contents

<b>Schedule of Submissions.....</b>	<b>2</b>
<b>I. Limitations and Monitoring Requirements .....</b>	<b>5</b>
A. Discharge Authorization .....	5
B. Effluent Limitations and Monitoring .....	5
C. Surface Water Monitoring .....	8
D. Whole Effluent Toxicity Testing Requirements .....	9
<b>II. Special Conditions.....</b>	<b>11</b>
A. Operation and Maintenance Plan .....	11
B. Quality Assurance Plan (QAP) .....	11
C. Requirements for Oversight of Industrial Users .....	12
D. Modification for Cause .....	12
<b>III. Monitoring, Recording and Reporting Requirements .....</b>	<b>13</b>
A. Representative Sampling (Routine and Non-Routine Discharges).....	13
B. Reporting of Monitoring Results .....	13
C. Monitoring Procedures.....	14
D. Additional Monitoring by Permittee .....	14
E. Records Contents .....	14
F. Retention of Records.....	14
G. Twenty-four Hour Notice of Noncompliance Reporting.....	14
H. Other Noncompliance Reporting .....	15
I. Notice of New Introduction of Toxic Pollutants.....	15
<b>IV. Compliance Responsibilities .....</b>	<b>16</b>
A. Duty to Comply.....	16
B. Penalties for Violations of Permit Conditions .....	16
C. Need To Halt or Reduce Activity not a Defense .....	18
D. Duty to Mitigate.....	18
E. Proper Operation and Maintenance .....	18
F. Bypass of Treatment Facilities.....	18
G. Upset Conditions.....	19
H. Toxic Pollutants .....	19
I. Planned Changes.....	20
J. Anticipated Noncompliance.....	20
K. Reopener .....	20
<b>V. General Provisions.....</b>	<b>20</b>
A. Permit Actions .....	20
B. Duty to Reapply .....	20
C. Duty to Provide Information.....	21
D. Other Information .....	21
E. Signatory Requirements.....	21

F.	Availability of Reports.....	22
G.	Inspection and Entry .....	22
H.	Property Rights .....	23
I.	Transfers .....	23
J.	State Laws.....	23
<b>VI.</b>	<b>Definitions.....</b>	<b>23</b>

## **I. Limitations and Monitoring Requirements**

### **A. Discharge Authorization**

1. During the effective period of this permit, the permittee is authorized to discharge pollutants from Outfall 001 to Indian Creek, within the limitations and subject to the conditions set forth herein. This permit authorizes the discharge of only those pollutants resulting from facility processes, waste streams, and operations that have been clearly identified in the permit application process.

### **B. Effluent Limitations and Monitoring**

1. The permittee must limit and monitor discharges from outfall 001 as specified in Table 1, below. All figures represent maximum effluent limitations unless otherwise indicated. The permittee must comply with the effluent limitations at all times unless otherwise indicated, regardless of the frequency of monitoring or reporting required by other provisions of this permit.
2. Phosphorus offset plan and phosphorus mass limits: Prior to discharging more than 1.1 lb/day of total phosphorus on a monthly average basis or more than 1.65 lb/day of total phosphorus on a weekly average basis during the season of May 1<sup>st</sup> through September 30<sup>th</sup>, the permittee must submit to EPA a plan that describes how the permittee will comply with IDAPA 58.01.02.054.04, including written documentation of IDEQ's approval of the plan. Prior to IDEQ approval of the plan, the average monthly discharge limitation for total phosphorus is 1.1 lb/day and the average weekly discharge limitation is 1.65 lb/day from May 1<sup>st</sup> through September 30<sup>th</sup>. After IDEQ approval of the plan, the average monthly discharge limitation for total phosphorus is 2.0 lb/day and the average weekly discharge limitation is 3.1 lb/day from May 1<sup>st</sup> through September 30<sup>th</sup>.
  - a) The plan must describe the measures the permittee will implement to ensure that the discharge from the Kuna facility is consistent with the 1.1 lb/day allocation identified in the Clean Water Act Section 401 Certification for this permit, including without limitation any measures the permittee will implement to ensure that any discharge of phosphorus that is in excess of 1.1 lb/day on a monthly average basis and/or more than 1.65 lb/day on a weekly average basis will be offset, from May 1<sup>st</sup> through September 30<sup>th</sup>.
  - b) The plan must include a schedule for implementation of the measures.
  - c) Once the plan is approved by IDEQ, the plan must be implemented according to the schedule in the approved plan.
3. The permittee must report within 24 hours any violation of the maximum daily limitations or instantaneous maximum limitations for the following pollutants: total residual chlorine, total ammonia as N, and Escherichia coli (E. coli). Violations of all other effluent limitations are to be reported at the time that Discharge Monitoring Reports (DMRs) are submitted (See III.B and III.H).

Table 1: Effluent Limitations and Monitoring Requirements							
Parameter	Units	Effluent Limitations			Monitoring Requirements		
		Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit	Sample Location	Sample Frequency	Sample Type
Flow	mgd	Report	—	Report	Effluent	continuous	Recorder
Biochemical Oxygen Demand (BOD <sub>5</sub> )	mg/L	30	45	—	Influent and Effluent	2/week	24-Hour Composite
	lb/day	876	1314	—			
	% removal	85% (min.)	—	—	% removal	1/month	Calculation
Total Suspended Solids	mg/L	30	45	—	Influent and Effluent	2/week	24-Hour Composite
	lb/day	876	1314	—			
	% removal	85% (min.)	—	—	% removal	1/month	Calculation
pH	s.u	6.3 – 9.0 at all times			Effluent	5/week	Grab
E. Coli Bacteria <sup>1,2</sup>	#/100 ml	126 (geometric mean)	—	576 (instantaneous maximum limit)	Effluent	5/month	Grab
Total Residual Chlorine <sup>2</sup>	µg/L	16	—	31	Effluent	1/month	Grab
	lb/day	0.46	—	0.92			
Total Ammonia as N <sup>2</sup>	mg/L	1.7	—	3.9	Effluent	2/week	24-Hour Composite
	lb/day	50	—	115			
Total Phosphorus as P (May 1 – September 30)	µg/L	70	105	Report	Influent and Effluent	2/week	24-Hour Composite
	lb/day	See I.B.2.		Report			
	% removal	Report	—	—	% removal	1/month	Calculation
Total Phosphorus as P (Oct. 1 – April 30)	mg/L	Report	—	Report	Effluent	1/month	24-Hour Composite
Temperature	°C	Report	—	Report	Effluent	5/week	Grab
Dissolved Oxygen	mg/L	Report minimum and average			Effluent	2/month	Grab
Alkalinity	mg/L as CaCO <sub>3</sub>	Report	—	Report	Effluent	1/quarter <sup>3</sup>	24-Hour Composite
Hardness	mg/L as CaCO <sub>3</sub>	Report	—	Report	Effluent	1/quarter <sup>3</sup>	24-Hour Composite
Total Kjeldahl Nitrogen	mg/L	Report	—	Report	Effluent	1/quarter <sup>3</sup>	24-Hour Composite
Nitrate Plus Nitrite Nitrogen	mg/L	Report	—	Report	Effluent	1/quarter <sup>3</sup>	24-Hour Composite
Oil and Grease	mg/L	Report	—	Report	Effluent	1/quarter <sup>3</sup>	Grab
Total Dissolved Solids	mg/L	Report	—	Report	Effluent	1/quarter <sup>3</sup>	24-Hour Composite
Expanded Effluent Testing, NPDES Application Form 2A, part D <sup>4</sup>	—	These data must be reported on the application for renewal of this NPDES permit. These data need not be reported on monthly DMRs. <sup>4</sup>			Effluent <sup>5</sup>	3x/5 years <sup>5</sup>	—
Whole Effluent Toxicity	TU <sub>c</sub>	Report on April and October DMRs (see I.D)			Effluent	2/year	24-Hour Composite

<b>Table 1: Effluent Limitations and Monitoring Requirements</b>							
<b>Parameter</b>	<b>Units</b>	<b>Effluent Limitations</b>			<b>Monitoring Requirements</b>		
		<b>Average Monthly Limit</b>	<b>Average Weekly Limit</b>	<b>Maximum Daily Limit</b>	<b>Sample Location</b>	<b>Sample Frequency</b>	<b>Sample Type</b>
Notes:							
1. The E. Coli bacteria counts must not exceed a monthly geometric mean of 126/100 ml and a single sample (instantaneous) maximum of 576 organisms per 100 ml. See Part VI for the definition of geometric mean.							
2. Reporting is required within 24 hours of a maximum daily limit or instantaneous maximum limit violation. See Parts I.B.3 and III.G.							
3. Quarters are defined as January through March, April through June, July through September, and October through December. Monitoring results for pollutants with a sample frequency of quarterly must be reported on the March, June, September and December DMRs.							
4. See I.B.10.							

4. The permittee must not discharge floating, suspended, or submerged matter of any kind in amounts causing nuisance or objectionable conditions or that may impair designated beneficial uses of the receiving water.
5. Removal Requirements for BOD<sub>5</sub> and TSS: The monthly average effluent concentration must not exceed 15 percent of the monthly average influent concentration. Percent removal of BOD<sub>5</sub> and TSS must be reported on the Discharge Monitoring Reports (DMRs). For each parameter, the monthly average percent removal must be calculated from the arithmetic mean of the influent values and the arithmetic mean of the effluent values for that month. Influent and effluent samples must be taken over approximately the same time period.
6. The permittee must collect effluent samples from the effluent stream after the last treatment unit prior to discharge into the receiving waters.
7. Minimum Quantification Levels. For all effluent monitoring, the permittee must use methods that can achieve a minimum quantification level (MQL) less than the effluent limitations. See Part VI for a definition of minimum quantification level. For parameters that do not have effluent limitations, the permittee must use methods that can achieve MQLs less than or equal to those specified in Table 2. If no minimum level is listed in Table 2 and the pollutant is not subject to an effluent limit, the permittee may use any EPA-approved method for analysis.

<b>Table 2: Maximum MQLs for Pollutants Not Subject to Effluent Limitations</b>		
<b>Parameter</b>	<b>Units</b>	<b>Maximum MQL</b>
Total Kjeldahl Nitrogen	µg/L	100
Nitrate – Nitrite as N	µg/L	50
Mercury (expanded effluent testing)	µg/L	0.01

8. For purposes of reporting on the DMR for a single sample, if a value is less than the MDL, the permittee must report “less than {numeric value of the MDL}” and if a value is less than the MQL, the permittee must report “less than {numeric value of the MQL}.”

9. For purposes of calculating monthly and weekly averages, zero may be assigned for values less than the MDL, and the {numeric value of the MDL} may be assigned for values between the MDL and the MQL. If the average value is less than the MDL, the permittee must report “less than {numeric value of the MDL}” and if the average value is less than the MQL, the permittee must report “less than {numeric value of the MQL}.” If a value is equal to or greater than the MQL, the permittee must report and use the actual value.
10. The permittee must perform the effluent testing required by Part D of NPDES application Form 2A (EPA Form 3510-2A, revised 1-99). The permittee must submit the results of this testing with its application for renewal of this NPDES permit. To the extent that effluent monitoring required by other conditions of this permit satisfies this requirement, these samples may be used to satisfy the requirements of this paragraph.

### C. Surface Water Monitoring

The permittee must conduct surface water monitoring. Surface water monitoring must begin in the first calendar month in which the permittee discharges pollutants to the receiving water and must continue as long as the permit remains in force. The program must meet the following requirements:

1. Monitoring stations must be established in the receiving water above and below the influence of the facility’s discharge.
2. To the extent practicable, surface water sample collection must occur on the same day as effluent sample collection.
3. All ambient samples must be grab samples.
4. Samples must be analyzed for the parameters listed in Table 3, and must achieve method detection limits (MDLs) that are equivalent to or less than those listed in Table 3. If no MDL is listed in Table 3, the permittee may use any EPA-approved method for analysis. The permittee may request different MDLs. The request must be in writing and must be approved by EPA.

<b>Table 3: Surface Water Monitoring Requirements</b>				
<b>Parameter (units)</b>	<b>Sample Locations</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Maximum MDL</b>
Flow (CFS)	Upstream	monthly	Measure	—
Total Ammonia as N (mg/L)	Upstream	monthly	Grab	0.03
pH (s.u)	Upstream	monthly	Grab	—
Phosphorus (µg/L)	Upstream and Downstream	monthly	Grab	10
Temperature (°C)	Upstream and Downstream	See note 1	Grab	—
Dissolved Oxygen (mg/L and percent of saturation)	Upstream and Downstream	See Note 1	Grab	—
Notes:				
1. Receiving water monitoring for temperature and dissolved oxygen must be performed at least once during the calendar months of March, April, May, June, July, August, September and October.				

5. Quality assurance/quality control plans for surface water monitoring must be documented in the Quality Assurance Plan required under Part II.B, "Quality Assurance Plan".
6. Surface water monitoring results must be submitted to EPA and IDEQ with the application for renewal of this permit (see V.B). At a minimum, the report must include the following:
  - a) Dates of sample collection and analyses.
  - b) Results of sample analysis.
  - c) Relevant quality assurance/quality control (QA/QC) information.
7. Annual written certification specifying that the Permittee has collected and analyzed surface water samples in accordance with all applicable conditions in this permit must be submitted to EPA and IDEQ with the December DMR.

#### **D. Whole Effluent Toxicity Testing Requirements**

The permittee must conduct chronic toxicity tests on effluent samples from outfall 001. Testing must be conducted in accordance with subsections 1 through 4, below.

1. Toxicity testing must be conducted on 24-hour composite samples of effluent. In addition, a split of each sample collected must be analyzed for the chemical and physical parameters required in Part 1.B above that have a required sampling frequently of quarterly or more frequently. When the timing of sample collection coincides with that of the sampling required in Part I.B, analysis of the split sample will fulfill the requirements of Part I.B as well.
2. Chronic Test Species and Methods
  - a) For outfall 001, chronic tests must be conducted twice per year, once during the period from May 1<sup>st</sup> through October 31<sup>st</sup>, and once during the period from November 1<sup>st</sup> through April 30<sup>th</sup>.
  - b) The permittee must conduct short-term tests with the water flea, *Ceriodaphnia dubia* (survival and reproduction test), and the fathead minnow, *Pimephales promelas* (larval survival and growth test), for the first three suites of tests. After this screening period, monitoring shall be conducted using the most sensitive species.
  - c) The presence of chronic toxicity must be determined as specified in *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA/821-R-02-013, October 2002.
  - d) Results must be reported in  $TU_c$  (chronic toxic units), where  $TU_c = 100/IC_{25}$ . See Part VI for a definition of  $IC_{25}$ .
3. Quality Assurance
  - a) The toxicity testing on each organism must include a series of five test dilutions and a control. The dilution series must include the receiving water

concentration (RWC), which is the dilution associated with the chronic toxicity trigger: two dilutions above the RWC, and two dilutions below the RWC. The RWC is 58% effluent.

- b) All quality assurance criteria and statistical analyses used for chronic tests and reference toxicant tests must be in accordance with *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA/821-R-02-013, October 2002, and individual test protocols.
- c) In addition to those quality assurance measures specified in the methodology, the following quality assurance procedures must be followed:
  - (i) If organisms are not cultured in-house, concurrent testing with reference toxicants must be conducted. If organisms are cultured in-house, monthly reference toxicant testing is sufficient. Reference toxicant tests must be conducted using the same test conditions as the effluent toxicity tests.
  - (ii) If either of the reference toxicant tests or the effluent tests do not meet all test acceptability criteria as specified in the test methods manual, the permittee must re-sample and re-test within 14 days of receipt of the test results.
  - (iii) Control and dilution water must be receiving water or lab water, as appropriate, as described in the manual. If the dilution water used is different from the culture water, a second control, using culture water must also be used. Receiving water may be used as control and dilution water upon prior notification to EPA and IDEQ. In no case shall water that has not met test acceptability criteria be used for either dilution or control.

#### 4. Reporting

- a) The permittee must submit the results of the toxicity tests with the discharge monitoring reports (DMR). Toxicity tests taken from May 1<sup>st</sup> through October 31<sup>st</sup> must be reported on the October DMR. Toxicity tests taken from November 1<sup>st</sup> through April 30<sup>th</sup> must be reported on the April DMR.
- b) The report of toxicity test results must include all relevant information outlined in Section 10, Report Preparation, of *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA/821-R-02-013, October 2002. In addition to toxicity test results, the permittee must report: dates of sample collection and initiation of each test; flow rate at the time of sample collection; and the results of the monitoring required in Part I.B.

## II. Special Conditions

### A. Operation and Maintenance Plan

In addition to the requirements specified in Section III.E of this permit (Proper Operation and Maintenance), by the effective date of this permit, the permittee must provide written notice to EPA and IDEQ that an operation and maintenance plan for the wastewater treatment facility has been developed. The permittee must provide written notice that the operation and maintenance plan has been implemented by the effective date of this permit. The plan shall be retained on site and made available on request to EPA and IDEQ.

### B. Quality Assurance Plan (QAP)

The permittee must develop a quality assurance plan (QAP) for all monitoring required by this permit. The permittee must submit written notice to EPA and IDEQ that the Plan has been developed by the effective date of the final permit. The permittee must provide written notification that the plan has been implemented by the effective date of this permit. Any existing QAPs may be modified for compliance with this section.

1. The QAP must be designed to assist in planning for the collection and analysis of effluent and receiving water samples in support of the permit and in explaining data anomalies when they occur.
2. Throughout all sample collection and analysis activities, the permittee must use the EPA-approved QA/QC and chain-of-custody procedures described in *Requirements for Quality Assurance Project Plans (EPA/QA/R-5)* and *Guidance for Quality Assurance Project Plans (EPA/QA/G-5)*. The QAP must be prepared in the format that is specified in these documents.
3. At a minimum, the QAP must include the following:
  - a) Details on the number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limitations for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements.
  - b) Map(s) indicating the location of each sampling point.
  - c) Qualification and training of personnel.
  - d) Name(s), address(es) and telephone number(s) of the laboratories used by or proposed to be used by the permittee.
4. The permittee must amend the QAP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAP.
5. Copies of the QAP must be kept on site and made available to EPA and/or IDEQ upon request.

### **C. Requirements for Oversight of Industrial Users**

The permittee must require any industrial user discharging to its treatment works to comply with any applicable requirements of 40 CFR 403 (as amended at 70 FR 60134) through 471, including the following requirements.

1. **General Prohibition:** The permittee must not allow any industrial user to introduce into the POTW any pollutant(s) which causes Pass Through or Interference. These general prohibitions and the specific prohibitions below apply to each industrial user introducing pollutants into the POTW whether or not the industrial user is subject to other National Pretreatment Standards or any national, State, or local Pretreatment Requirements.
2. **Specific Prohibitions:** The permittee must not allow industrial users to discharge the following pollutants into the POTW:
  - a) Pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, wastestreams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21.
  - b) Pollutants which will cause corrosive structural damage to the POTW, but in no case Discharges with pH lower than 5.0, unless the works is specifically designed to accommodate such Discharges.
  - c) Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW resulting in Interference.
  - d) Any pollutant, including oxygen demanding pollutants (BOD, etc.) released in a Discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW.
  - e) Heat in amounts which will inhibit biological activity in the POTW resulting in Interference, but in no case heat in such quantities that the temperature at the POTW Treatment Plant exceeds 40 °C (104 °F) unless the Director of the Office of Water and Watersheds, upon request of the POTW, approves alternate temperature limits.
  - f) Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through.
  - g) Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems.
  - h) Any trucked or hauled pollutants, except at discharge points designated by the POTW.

### **D. Modification for Cause**

This permit may be modified for cause in compliance with 40 CFR 122.62. Causes for modification include, but are not limited to, new information which was not available at the time of permit issuance and which would have justified the

application of different permit conditions at the time of issuance. A wasteload allocation for the permitted discharge in an approved total maximum daily load established pursuant to 40 CFR 130.7 would be considered new information.

### **III. Monitoring, Recording and Reporting Requirements**

#### **A. Representative Sampling (Routine and Non-Routine Discharges)**

Samples and measurements must be representative of the volume and nature of the monitored discharge.

In order to ensure that the effluent limits set forth in this permit are not violated at times other than when routine samples are taken, the permittee must collect additional samples at the appropriate outfall whenever any non-routine discharge from the permitted point source occurs which may reasonably be expected to cause or contribute to a violation of any effluent limit that is unlikely to be detected by a routine sample. The non-routine discharge may be due to a spill, bypass, or upset within the permitted facility, or a non-complying indirect discharge from an industrial user. The terms “bypass,” “discharge,” “indirect discharge,” and “upset” are defined in Part VI of this permit.

The permittee must collect such additional samples as soon as the non-routine discharge reaches the outfall. The permittee must analyze the additional samples for those parameters limited in Part I.B of this permit that are likely to be affected by the non-routine discharge. The samples must be analyzed in accordance with paragraph III.C (“Monitoring Procedures”). The permittee must report all additional monitoring in accordance with paragraph III.D (“Additional Monitoring by Permittee”).

#### **B. Reporting of Monitoring Results**

The permittee must summarize monitoring results each month on the Discharge Monitoring Report (DMR) form (EPA No. 3320-1) or equivalent. The permittee must submit reports monthly, postmarked by the 20th day of the following month. If the permittee does not discharge for that month, then “no discharge” shall be reported on the DMR. The permittee must sign and certify all DMRs, and all other reports, in accordance with the requirements of Part V.E of this permit (“Signatory Requirements”). The permittee must submit the legible originals of these documents to the Director, Office of Compliance and Enforcement, with copies to IDEQ at the following addresses:

US EPA Region 10  
Attn: ICIS Data Entry Team  
1200 Sixth Avenue Suite 900  
M/S OCE-133  
Seattle, Washington 98101

Idaho Department of Environmental Quality  
1445 North Orchard  
Boise, ID 83706

**C. Monitoring Procedures**

Monitoring must be conducted according to test procedures approved under 40 CFR 136, unless other test procedures have been specified in this permit or approved by EPA as an alternate test procedure under 40 CFR 136.5.

**D. Additional Monitoring by Permittee**

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR 136 or as specified in this permit, the permittee must include the results of this monitoring in the calculation and reporting of the data submitted in the DMR.

Upon request by EPA, the permittee must submit results of any other sampling, regardless of the test method used.

**E. Records Contents**

Records of monitoring information must include:

1. the date, exact place, and time of sampling or measurements;
2. the name(s) of the individual(s) who performed the sampling or measurements;
3. the date(s) analyses were performed;
4. the names of the individual(s) who performed the analyses;
5. the analytical techniques or methods used; and
6. the results of such analyses.

**F. Retention of Records**

The permittee must retain records of all monitoring information, including, all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, copies of DMRs, a copy of the NPDES permit, and records of all data used to complete the application for this permit, for a period of at least five years from the date of the sample, measurement, report or application. This period may be extended by request of EPA or IDEQ at any time.

**G. Twenty-four Hour Notice of Noncompliance Reporting**

1. The permittee must report the following occurrences of noncompliance by telephone within 24 hours from the time the permittee becomes aware of the circumstances:
  - a) any noncompliance that may endanger health or the environment;
  - b) any unanticipated bypass that exceeds any effluent limitation in the permit (See Part IV.F, "Bypass of Treatment Facilities");
  - c) any upset that exceeds any effluent limitation in the permit (See Part IV.G, "Upset Conditions"); or

- d) any violation of a maximum daily discharge limitation for applicable pollutants identified by Part I.B.2.
  - e) any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limitation in the permit.
2. The permittee must also provide a written submission within five days of the time that the permittee becomes aware of any event required to be reported under subpart 1 above. The written submission must contain:
    - a) a description of the noncompliance and its cause;
    - b) the period of noncompliance, including exact dates and times;
    - c) the estimated time noncompliance is expected to continue if it has not been corrected; and
    - d) steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
    - e) if the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.
  3. The Director of the Office of Compliance and Enforcement may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the NPDES Compliance Hotline in Seattle, Washington, by telephone, (206) 553-1846.
  4. Reports must be submitted to the addresses in Part III.B (“Reporting of Monitoring Results”).

#### **H. Other Noncompliance Reporting**

The permittee must report all instances of noncompliance, not required to be reported within 24 hours, at the time that monitoring reports for Part III.B (“Reporting of Monitoring Results”) are submitted. The reports must contain the information listed in Part III.G.2 of this permit (“Twenty-four Hour Notice of Noncompliance Reporting”).

#### **I. Notice of New Introduction of Toxic Pollutants**

The permittee must notify the Director of the Office of Water and Watersheds and IDEQ in writing of:

1. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to Sections 301 or 306 of the Act if it were directly discharging those pollutants; and
2. Any substantial change in the volume or character of pollutants being introduced into the POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
3. For the purposes of this section, adequate notice must include information on:

- a) The quality and quantity of effluent to be introduced into the POTW, and
  - b) Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
4. The permittee must notify the Director of the Office of Water and Watersheds at the following address:

US EPA Region 10  
Attn: NPDES Permits Unit Manager  
1200 6<sup>th</sup> Avenue Suite 900  
M/S OWW-130  
Seattle, WA 98101

## **IV. Compliance Responsibilities**

### **A. Duty to Comply**

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification, or for denial of a permit renewal application.

### **B. Penalties for Violations of Permit Conditions**

1. **Civil and Administrative Penalties.** Pursuant to 40 CFR Part 19 and the Act, any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed the maximum amounts authorized by Section 309(d) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$37,500 per day for each violation).
2. **Administrative Penalties.** Any person may be assessed an administrative penalty by the Administrator for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Pursuant to 40 CFR 19 and the Act, administrative penalties for Class I violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(A) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$16,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$37,500). Pursuant to 40 CFR 19 and the Act, penalties for Class II violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(B) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$16,000 per day for each day during which the

violation continues, with the maximum amount of any Class II penalty not to exceed \$177,500).

3. Criminal Penalties:

- a) **Negligent Violations.** The Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.
- b) **Knowing Violations.** Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.
- c) **Knowing Endangerment.** Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the Act, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.
- d) **False Statements.** The Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. The Act further provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-

compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

**C. Need To Halt or Reduce Activity not a Defense**

It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with this permit.

**D. Duty to Mitigate**

The permittee must take all reasonable steps to minimize or prevent any discharge in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

**E. Proper Operation and Maintenance**

The permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

**F. Bypass of Treatment Facilities**

1. Bypass not exceeding limitations. The permittee may allow any bypass to occur that does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2 and 3 of this Part.
2. Notice.
  - a) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it must submit prior written notice, if possible at least 10 days before the date of the bypass.
  - b) Unanticipated bypass. The permittee must submit notice of an unanticipated bypass as required under Part III.G (“Twenty-four Hour Notice of Noncompliance Reporting”).
3. Prohibition of bypass.
  - a) Bypass is prohibited, and the Director of the Office of Compliance and Enforcement may take enforcement action against the permittee for a bypass, unless:
    - (i) The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

- (ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance; and
  - (iii) The permittee submitted notices as required under paragraph 2 of this Part.
- b) The Director of the Office of Compliance and Enforcement may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 3.a. of this Part.

### **G. Upset Conditions**

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the permittee meets the requirements of paragraph 2 of this Part. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
2. Conditions necessary for a demonstration of upset. To establish the affirmative defense of upset, the permittee must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - a) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - b) The permitted facility was at the time being properly operated;
  - c) The permittee submitted notice of the upset as required under Part III.G, “Twenty-four Hour Notice of Noncompliance Reporting;” and
  - d) The permittee complied with any remedial measures required under Part IV.D, “Duty to Mitigate.”
3. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

### **H. Toxic Pollutants**

The permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

**I. Planned Changes**

The permittee must give written notice to the Director of the Office of Water and Watersheds as specified in part III.I.4 and IDEQ as soon as possible of any planned physical alterations or additions to the permitted facility whenever:

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as determined in 40 CFR 122.29(b); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this permit.
3. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application site.

**J. Anticipated Noncompliance**

The permittee must give written advance notice to the Director of the Office of Compliance and Enforcement and IDEQ of any planned changes in the permitted facility or activity that may result in noncompliance with this permit.

**K. Reopener**

This permit may be reopened to include any applicable standard for sewage sludge use or disposal promulgated under section 405(d) of the Act. The Director may modify or revoke and reissue the permit if the standard for sewage sludge use or disposal is more stringent than any requirements for sludge use or disposal in the permit, or controls a pollutant or practice not limited in the permit.

**V. General Provisions****A. Permit Actions**

This permit may be modified, revoked and reissued, or terminated for cause as specified in 40 CFR 122.62, 122.64, or 124.5. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**B. Duty to Reapply**

If the permittee intends to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. In accordance with 40 CFR 122.21(d), and unless permission for the application to be submitted at a later date has been granted by the Regional Administrator, the

permittee must submit a new application at least 180 days before the expiration date of this permit.

### **C. Duty to Provide Information**

The permittee must furnish to EPA and IDEQ, within the time specified in the request, any information that EPA or IDEQ may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee must also furnish to EPA or IDEQ, upon request, copies of records required to be kept by this permit.

### **D. Other Information**

When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or that it submitted incorrect information in a permit application or any report to EPA or IDEQ, it must promptly submit the omitted facts or corrected information in writing.

### **E. Signatory Requirements**

All applications, reports or information submitted to EPA and IDEQ must be signed and certified as follows.

1. All permit applications must be signed as follows:
  - a) For a corporation: by a responsible corporate officer.
  - b) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively.
  - c) For a municipality, state, federal, Indian tribe, or other public agency: by either a principal executive officer or ranking elected official.
2. All reports required by the permit and other information requested by EPA or IDEQ must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a) The authorization is made in writing by a person described above;
  - b) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company; and
  - c) The written authorization is submitted to the Director of the Office of Compliance and Enforcement and IDEQ.
3. Changes to authorization. If an authorization under Part V.E.2 is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part V.E.2 must be submitted to the Director of the Office of Compliance and

Enforcement and IDEQ prior to or together with any reports, information, or applications to be signed by an authorized representative.

4. Certification. Any person signing a document under this Part must make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

#### **F. Availability of Reports**

In accordance with 40 CFR 2, information submitted to EPA pursuant to this permit may be claimed as confidential by the permittee. In accordance with the Act, permit applications, permits and effluent data are not considered confidential. Any confidentiality claim must be asserted at the time of submission by stamping the words “confidential business information” on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice to the permittee. If a claim is asserted, the information will be treated in accordance with the procedures in 40 CFR 2, Subpart B (Public Information) and 41 Fed. Reg. 36902 through 36924 (September 1, 1976), as amended.

#### **G. Inspection and Entry**

The permittee must allow the Director of the Office of Compliance and Enforcement, EPA Region 10; IDEQ; or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location.

## **H. Property Rights**

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any injury to persons or property or invasion of other private rights, nor any infringement of federal, tribal, state or local laws or regulations.

## **I. Transfers**

This permit is not transferable to any person except after written notice to the Director of the Office of Water and Watersheds as specified in part III.I.4. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act. (See 40 CFR 122.61; in some cases, modification or revocation and reissuance is mandatory).

## **J. State Laws**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Act.

## **VI. Definitions**

1. "Act" means the Clean Water Act.
2. "Administrator" means the Administrator of the EPA, or an authorized representative.
3. "Average monthly discharge limitation" means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month.
4. "Average weekly discharge limitation" means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week.
5. "Best Management Practices" (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the United States. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage areas.
6. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility.
7. "Composite" - see "24-hour composite".

8. “Daily discharge” means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the “daily discharge” is calculated as the average measurement of the pollutant over the day.
9. “Director of the Office of Compliance and Enforcement” means the Director of the Office of Compliance and Enforcement, EPA Region 10, or an authorized representative.
10. “Director of the Office of Water and Watersheds” means the Director of the Office of Water and Watersheds, EPA Region 10, or an authorized representative.
11. “Discharge” or “discharge of pollutants” is defined in 40 CFR 122.2.
12. “DMR” means discharge monitoring report.
13. “EPA” means the United States Environmental Protection Agency.
14. “Grab” sample is an individual sample collected over a period of time not exceeding 15 minutes.
15. “IDEQ” means the Idaho Department of Environmental Quality.
16. “Indirect discharge” means the introduction of pollutants into a POTW from any non-domestic source regulated under Section 307(b), (c), or (d) of the Clean Water Act.
17. “Interference” is defined in 40 CFR 403.3.
18. “Interim Minimum Level (IML)” is used when a method-specific “Minimum Level (ML)” has not been published by EPA. The IML is equal to 3.18 times the method-specified “Method Detection Limit (MDL)”. The IML for non-metals is rounded to the nearest multiple of 2, 5, 10, 20, 50. this last sentence is only needed if the permit specifies IMLs for non-metals.
19. “LC50” means the concentration of toxicant (e.g., effluent) which is lethal to 50 percent of the test organisms exposed in the time period prescribed by the test.
20. “Maximum daily discharge limitation” means the highest allowable “daily discharge.”
21. “Method Detection Limit (MDL)” means the minimum concentration of a substance (analyte) that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero and is determined from analysis of a sample in a given matrix containing the analyte.
22. “Minimum Quantification Level (MQL)” means the constituent concentration that produces a signal sufficiently greater than the blank that it can be detected within specified limits by good laboratories during routine operations. Typically it is the concentration that produces a signal ten standard deviations above the reagent water blank signal.

23. “NOEC” means no observed effect concentration. The NOEC is the highest concentration of toxicant (e.g., effluent) to which organisms are exposed in a chronic toxicity test [full life-cycle or partial life-cycle (short term) test], that causes no observable adverse effects on the test organisms (i.e., the highest concentration of effluent in which the values for the observed responses are not statistically significantly different from the controls).
24. “NPDES” means National Pollutant Discharge Elimination System, the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits . . . under sections 307, 402, 318, and 405 of the CWA.
25. “Pass Through” means a Discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).
26. “QA/QC” means quality assurance/quality control.
27. “Regional Administrator” means the Regional Administrator of Region 10 of the EPA, or the authorized representative of the Regional Administrator.
28. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
29. “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
30. “24-hour composite” sample means a combination of at least 8 discrete sample aliquots of at least 100 milliliters, collected over periodic intervals from the same location, during the operating hours of a facility over a 24 hour period. The composite must be flow proportional. The sample aliquots must be collected and stored in accordance with procedures prescribed in the most recent edition of Standard Methods for the Examination of Water and Wastewater.