

Idaho Department of Environmental Quality
Reuse Permit
DMI-267-01

Table 1. Facility Information

Facility Name	City of Boise – Molenaar Park Splash Pad
Facility location	Molenaar Park near intersection of W Victory Road and S Maple Grove Road, Boise, Idaho 83709, Ada County
Facility mailing address	1104 Royal Blvd, Boise, Idaho 83706
Facility contact	<p>Responsible Official: City of Boise Mayor</p> <p>Authorized Representative: Sara Arkle, City of Boise Parks Resource Superintendent (208) 493-2533 sarkle@cityofboise.org</p> <p>Notify DEQ within 30 days if there is a change in personnel for the above facility contact. A minor permit modification will be issued by the Idaho Department of Environmental Quality (DEQ) to confirm the change.</p>

Table 2. Permit Limits and Conditions

Parameter	Permit Conditions
Public Health Hazard or Nuisance Condition	Activities covered under this permit must not create a public health hazard or nuisance condition, as stated in the <i>Wastewater Rules</i> , IDAPA 58.01.16.600.03.
Ground Water	The activities covered under this permit shall not cause a violation of the <i>Ground Water Quality Rule</i> , IDAPA 58.01.11.
Surface Water	The activities covered under this permit shall not cause a violation of the water quality standards in the <i>Water Quality Standards</i> , IDAPA 58.01.02.
Entry and Access	The permittee shall allow DEQ entry and access to inspect the facility in accordance with the <i>Recycled Water Rules</i> , IDAPA 58.01.17.500.05.
Reporting	The permittee shall report changes, non-compliances, and other relevant facts in accordance with the <i>Recycled Water Rules</i> , IDAPA 58.01.17.500.06.
Condition no. 1	This permit covers reuse of water generated from the splash pad, disinfected, and discharged to park pond prior to use in the irrigation system.
Condition no. 2	Application may occur only in the area identified in the permit application materials and shown in Figure 1.
Condition no. 3	An Operation and Maintenance Manual shall be submitted to DEQ for approval within 6 months of permit issuance. The treatment system shall receive regular maintenance as described in the Operation and Maintenance Manual, or as amended and approved by DEQ.
Condition no. 4	All supplemental irrigation water sources, including the irrigation well and pond supply ditch, shall be protected from recycled water backflow by an approved backflow prevention device or air gap approved by DEQ. Where a backflow prevention device is used, the assembly shall be tested annually.
Recordkeeping	An Annual Operational Summary documenting compliance with conditions 1, 2, 3 and 4

	shall be maintained on site, including any supporting documents used to demonstrate compliance. The Annual Operational Summary documents shall be maintained and accessible by Boise Parks and Recreation Staff for a minimum of 5 years from the date of each annual certification.
--	--



Figure 1 Reuse Irrigation Area

City of Boise – Molenaar Park Splash Pad (hereafter “permittee”) is hereby authorized to construct, install, and operate a reuse facility in accordance with (1) this permit; and (2) IDAPA 58.01.17 “Recycled Water Rules.” To maintain this permit, the responsible official for the permittee must sign and certify annually in writing that the facility operation and conditions upon which this permit was granted have not changed, including the basis for that assessment. Certification is due no later than January 31 of each year at the following address:

Engineering Manager
DEQ, Boise Regional Office
1445 N. Orchard
Boise, ID 83706

DEQ reserves the right to revoke the permit for the reasons set forth in IDAPA 58.01.17.920. This permit

does not relieve the permittee from responsibility for compliance with other applicable federal, state, or local laws, rules, standards, and ordinances.

This permit is effective from the date of signature and expires on May 24, 2032.

Signed,



Aaron Scheff, Administrator
Boise Regional Office
Idaho Department of Environmental Quality

5/26/22

Date