

Idaho Department of Environmental Quality Reuse Permit M-047-04

(Previous Permit No. M-047-03)

City of Ashton (hereafter "permittee") is hereby authorized to construct, install, and operate a reuse facility in accordance with (1) this permit; (2) IDAPA 58.01.17 "Recycled Water Rules"; (3) an approved plan of operation; and (4) all other applicable federal, state, and local laws, statutes, and rules. This permit is effective from the date of signature and expires on January 11, 2036.



Jan 14, 2026

Signature

Date

Troy Saffle

Regional Administrator
Idaho Falls Regional Office
Idaho Department of Environmental Quality

Idaho Department of Environmental Quality
Idaho Falls Regional Office
900 N Skyline, Suite B
(208) 528-2650

Accessibility Services: The Idaho Department of Environmental Quality will provide reasonable language access services and/or disability services for documents at no charge. To request an accommodation under Title VI of the Civil Rights Act of 1964 or Americans with Disabilities Act, contact DEQ's nondiscrimination coordinator at (208) 373-0271 or accessibility@deq.idaho.gov. Para obtener información en español, visite <https://www.deq.idaho.gov/about-us/accessibility/>.

This page intentionally left blank for correct double-sided printing.

Table of Contents

1. Common Acronyms/Abbreviations and Definitions	5
2. Facility Information	7
3. Compliance Schedule for Required Activities	8
4. Permit Limits and Conditions	12
4.1 Management Unit Descriptions	12
4.2 Hydraulic Loading Limits	12
4.3 Constituent Loading Limits	12
4.4 Management Unit Buffer Zones	13
4.5 Other Permit Limits and Conditions	13
5. Monitoring Requirements	15
5.1 Recycled Water and Supplemental Irrigation Water Sampling and Analyses	15
5.1.1 Constituent Monitoring	15
5.1.2 Management Unit and Other Flow Monitoring	15
5.2 Groundwater Monitoring	16
5.2.1 Groundwater Monitoring Point Descriptions	16
5.2.2 Ground Water Monitoring, Sampling, and Analyses	16
5.3 Soil Monitoring	17
5.3.1 Soil Monitoring Unit Descriptions	17
5.3.2 Soil Monitoring, Sampling, and Analyses	17
5.4 Crop Monitoring	17
5.4.1 Crop Harvest Monitoring	17
5.4.2 Plant Tissue Monitoring	18
5.5 Lagoon Information	18
6. Reporting Requirements	19
6.1 Annual Report Requirements	19
6.1.1 Due Date	19
6.1.2 Required Contents	19
6.1.3 Submittals	20
6.2 Emergency and Noncompliance Reporting	22
7. Reserved	23
8. Standard Permit Conditions	23
9. General Permit Conditions	25
9.1 Operations	25
9.1.1 Backflow Prevention	25
9.1.2 Restricted to Premises	25
9.1.3 Solids Management	26
9.1.4 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801)	27
9.1.5 Plan of Operation (IDAPA 58.01.17.300.05)	27
9.1.6 Seepage Testing Requirements (IDAPA 58.01.16.493.02.c)	27
9.1.7 Ground Water Quality Rule (IDAPA 58.01.11)	27

9.2 Administrative.....	28
9.2.1 Permit Modification (IDAPA 58.01.17.700)	28
9.2.2 Permit Transferable (IDAPA 58.01.17.800)	28
9.2.3 Permit Revocation (IDAPA 58.01.17.920).....	28
9.2.4 Severability	29
10. Other Applicable Laws	30
10.1 Owner Responsibilities for Well Use and Maintenance	30
10.1.1 Well Use.....	30
10.1.2 Well Maintenance	30
10.1.3 Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Groundwater Resource	30
11. Site Maps.....	31
11.1 Regional Map	31
11.2 Facility Map.....	32

1. Common Acronyms/Abbreviations and Definitions

CA	compliance activity
COD	chemical oxygen demand
crop uptake	those constituents assimilated by the crop from the soil, and those from applied fertilizer, biosolids and other soil amendments, recycled water, irrigation water, and other sources. Crop uptake excludes those constituents assimilated from the atmosphere, such as gaseous nitrogen fixed by legumes. Crop uptake plus atmospheric assimilated constituents equals crop content.
cwt	a unit of weight measurement equal to 100 pounds
DEQ	Idaho Department of Environmental Quality
director	DEQ director or designee unless otherwise specified
E _i	irrigation efficiency
EPA	United States Environmental Protection Agency
FM	prefix for flow measurement/monitoring location, device, or method reporting serial number
GW	prefix for groundwater reporting serial number
IDAPA	Numbering designation for all administrative rules in Idaho promulgated according to the Idaho Administrative Procedure Act
IDWR	Idaho Department of Water Resources
IPDES	Idaho Pollutant Discharge Elimination System
IWR	irrigation water requirement — any combination of wastewater and supplemental irrigation water applied at rates commensurate to the moisture requirements of the crop, and calculated monthly during the growing season.
lb	pound
LG	prefix for lagoon reporting serial number
material change	a change in a document required by this permit that would impact DEQ's ability to ensure compliance and protect human health and the environment
µmhos/cm	micromhos per centimeter
MG	million gallons

mg/kg	milligram per kilogram
mg/L	milligram per liter
mL	milliliter
MU	management unit, prefix for management unit reporting environmental serial number
NPDES	National Pollutant Discharge Elimination System
N	nitrogen
ppm	parts per million
P	phosphorus
PO	plan of operation
QAPP	quality assurance project plan
responsible official	facility contact person authorized by the permittee to communicate with DEQ on behalf of the permittee on any matter related to the permit, including without limitation, the authority to communicate with and receive notices from DEQ regarding notices of violation or non-compliance, permit violations, permit enforcement, and permit revocation. The responsible official provides written certification of permit application materials, annual report submittals, and other information submitted to DEQ as required by the permit. Any notice to or communication with the responsible official is considered a notice to or communication with the permittee. The responsible official may designate an authorized representative to act as the facility contact person for any of the activities or duties related to the permit, except signing and certifying the permit application, which must be done by the responsible official. The authorized representative must act as the responsible official and will bind the permittee as described in this definition. Designation of the authorized representative must follow the requirements specified in section 6.1.3 of the permit.
SU	prefix for soil monitoring unit reporting serial number
SW	prefix for supplemental irrigation water reporting serial number
WW	prefix for wastewater reporting serial number

2. Facility Information

Information Type	Information Specific to This Permit
Class or Type of recycled water	Municipal, Class C recycled water
Method of treatment and reuse	Aerated lagoons, chlorine disinfection, slow rate land application.
Collection and treatment system classification	Wastewater collection system classification: Class I Wastewater treatment system classification: Class I Land Application/Reuse
Facility location	The facility and adjacent land application areas are located ½ mile north of Ashton and ¼ mile west of the Highway 20/Tesoro Station intersection. Township 9N, Range 42E, Section 26 USGS quadrangle map: Ashton, ID
Facility mailing address	City of Ashton PO Box 689 Ashton, ID 83420
Facility responsible official and authorized representative	Responsible Official: Mayor Tom Mattingly City of Ashton, PO Box 689, Ashton, ID 83420 Phone: (208) 652-3987; Fax: (208) 652-3401 Email: tmattingly@cityofashton.com Authorized Representative: Justin Angell, City of Ashton, PO Box 689, Ashton, ID 83420 Phone: (208) 652-3987; Fax: (208) 652-3401 Email: wastewater@ashtonid.gov Notify DEQ within 30 days if a change in personnel occurs for any of the facility contacts. DEQ will issue a minor permit modification to confirm the change.
Groundwater	Typically 3.3 to 8.2 feet bgs to first encountered water; 3 to 4 feet bgs to spring seasonal high groundwater. Flow is to N or NE. 200 feet to the regional Snake River Plain Aquifer, flow is NE to SW. Beneficial uses: public/domestic water supply, agriculture Nearest Public Water Supply Well is approximately 3600 feet south.
Surface water	Unnamed stream (referred to as Sewer Creek): Approx. 50 feet east of the MU and west of the lagoons. Flows to Spring Creek, then to Ashton Reservoir (Henry's Fork). Farmer's Own Canal: Approx. 50 feet west of the MU. Provides supplemental irrigation.

3. Compliance Schedule for Required Activities

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-047-01 As specified	<p>Plan of Operation Evaluation for Disinfection Requirements: The permittee must review its PO within six (6) months for the operation and management of the facility’s treatment system for achieving disinfection requirements. The permittee may be required to update the PO if it does not effectively address the operation of the treatment systems in order to maintain compliance with permit limits, including the disinfection limit. In that case, a disinfection system assessment and improvement plan must be submitted for DEQ review and incorporated as part of the PO within twelve (12 months) of permit issuance. The assessment must contain, at minimum, a discussion of:</p> <ol style="list-style-type: none"> 1. The treatment system’s ability to meet Class C disinfection requirements. 2. Identification of system challenges. 3. Recommendations to correct system challenges. 4. Implementation schedule for any improvements deemed necessary. <p>Once approved, the plan is incorporated into the permit and is enforceable by reference. All improvements must be implemented in the schedule specified in the plan</p>

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-047-02 Within twelve (12) months of permit issuance	<p>Quality Assurance Project Plan (QAPP): The permittee must prepare and implement a QAPP that incorporates all monitoring and reporting required by this permit. A copy of the QAPP along with written notice that the permittee has implemented the QAPP must be provided to DEQ. The Permittee must follow the QAPP when collecting, analyzing, and reporting monitoring data submitted to DEQ.</p> <p>The QAPP must be designed to assist in planning for collecting, analyzing, and reporting all monitoring in support of this permit and in explaining data anomalies when they occur. At a minimum, the QAPP must include the following:</p> <ol style="list-style-type: none"> 1. Details on the number of measurements, number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements 2. Maps indicating the location of each monitoring and sampling point 3. Qualification and training of personnel 4. Names, addresses, and telephone numbers of the laboratories used by or proposed to be used by the permittee 5. Example formats and tables that will be used by the permittee to summarize and present all data in the annual report <p>The format and content of the QAPP should adhere to the recommendations and references in the Quality Assurance and Data Processing sections of the reuse guidance.</p> <p>The permittee must amend the QAPP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAPP. The permittee must notify DEQ of material changes to the QAPP and copies must be kept on site and made available to DEQ upon request.</p>

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description												
CA-047-03 Within twelve (12) months of permit issuance	<p>Plan of Operation (PO): The permittee must submit to DEQ for review and approval an updated PO that reflects current operations and incorporates the requirements of this permit. The updated PO must comply with the applicable requirements stated in IDAPA 58.01.17.300.05 and must address applicable items in the most current Plan of Operations Checklist available.</p> <p>The updated PO must include the following site management plans or the permittee may submit the site management plans individually:</p> <ol style="list-style-type: none"> 1. Runoff management plan 2. Buffer zone management plan 3. Irrigation scheduling and management plan 4. Evaporator management plan^a <p>The PO must be updated as needed to reflect current operations. The permittee must notify DEQ of material changes to the PO and copies must be kept on site and made available to DEQ upon request.</p> <ol style="list-style-type: none"> a. Evaporator usage is not allowed until the evaporator management plan is submitted and approved by DEQ. 												
CA-047-04 As specified	<p>Seepage Testing: The following table shows the date by which the permittee must complete seepage testing on the specified lagoons:</p> <table border="1" data-bbox="461 1104 1349 1373"> <thead> <tr> <th>Lagoon:</th> <th>Seepage Test Due Date:</th> </tr> </thead> <tbody> <tr> <td>LG-047-01; Cell 1</td> <td>September 2030</td> </tr> <tr> <td>LG-047-02; Cell 2</td> <td>September 2030</td> </tr> <tr> <td>LG-047-03; Cell 3</td> <td>September 2030</td> </tr> <tr> <td>LG-047-04; Cell 4</td> <td>September 2030</td> </tr> <tr> <td>LG-047-05; Cell 5; Winter Storage Lagoon</td> <td>November 2028</td> </tr> </tbody> </table> <p>Submit to DEQ for review and approval a proposed schedule and procedure for performing the required seepage tests at least 45 days before to the planned seepage test. The seepage test procedures must be sealed by the Idaho licensed professional engineer or professional geologist in responsible charge for the test.</p> <p>Seepage tests must be completed according to the procedures approved by DEQ. The seepage test report must be sealed by the person in responsible charge and submitted within 90 days after completion of the seepage test.</p> <p>Allowable seepage rates can be found in IDAPA 58.01.16.493.03. Requirements for lagoons leaking above the allowable amount are outlined in IDAPA 58.01.16.493.04.</p>	Lagoon:	Seepage Test Due Date:	LG-047-01; Cell 1	September 2030	LG-047-02; Cell 2	September 2030	LG-047-03; Cell 3	September 2030	LG-047-04; Cell 4	September 2030	LG-047-05; Cell 5; Winter Storage Lagoon	November 2028
Lagoon:	Seepage Test Due Date:												
LG-047-01; Cell 1	September 2030												
LG-047-02; Cell 2	September 2030												
LG-047-03; Cell 3	September 2030												
LG-047-04; Cell 4	September 2030												
LG-047-05; Cell 5; Winter Storage Lagoon	November 2028												
CA-047-05 12 months prior to permit expiration	<p>Pre-application Conference: If the permittee intends to continue operating the reuse facility beyond the expiration date of this permit, the permittee must contact DEQ and schedule a pre-application conference to discuss the compliance status of the facility and the content required for the reuse permit application package.</p>												

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-047-06 6 months prior to permit expiration	Permit Renewal Application: The permittee must submit to DEQ a complete permit renewal application package that fulfills the requirements specified in CA-047-05 and identified at the pre-application conference.

4. Permit Limits and Conditions

4.1 Management Unit Descriptions

Serial Number	Description	Irrigation System Type and Irrigation Efficiency (E _i)	Maximum Acres ^a Allowed
MU-047-01	Application Area	Pivot (E _i = 0.85)	77
Evaporator: see section 4.5 Other Permit Limits and Conditions for evaporator restrictions.			0 ^b
Total acreage			77

- a. Maximum acres represent the total permitted acreage of the MU as provided by the permittee. If the permittee uses less acreage in any season or year, then loading rates must be presented and compliance must be determined based on the actual acreage used during each season or year.
- b. The evaporator operates adjacent to LG-047-05. There is no acreage involved as non-evaporated water will spray back into the lagoon.

4.2 Hydraulic Loading Limits

Serial Number	Growing Season Hydraulic Loading	Nongrowing Season Maximum Hydraulic Loading (inches) ^a
MU-047-01	Substantially at the irrigation water requirement (IWR) ^b	Not allowed

- a. Record daily, as necessary, abnormal conditions as a result of nongrowing season application including ponding, excessive ice buildup, or runoff from the permitted site.
- b. For compliance purposes, the method for calculating the IWR must be specified in the PO.

4.3 Constituent Loading Limits

Serial Number	Constituent Loading from All Sources
MU-047-01	Nitrogen (lb/acre): 150% of typical crop uptake ^{a,b}

- a. Typical crop uptake is the median constituent crop uptake from the three most recent years the crop has been grown. For crops having fewer than three years of on-site crop uptake data, other crop yield data or nutrient content values may only be used if DEQ provides written approval before growing season.
- b. Crop uptake for nitrogen-fixing crops, defined here as legumes, must be calculated by assuming 15% of crop nitrogen content is fixed from the atmosphere. Other values for the proportion of crop nitrogen content fixed from the atmosphere may be used if DEQ provides written approval before beginning of the growing season.

4.4 Management Unit Buffer Zones

Serial Number	Buffer Distances (feet) from Management Units					
	Public Water Supplies	Private Water Supplies	Inhabited Dwellings	Permanent and Intermittent Surface Water	Irrigation Ditches and Canals	Areas Accessible to the Public
MU-047-01	1,000	500	300	100	50	500

4.5 Other Permit Limits and Conditions

Category	Permit Limits and Conditions
Growing season	April 1 through October 31 (214 days)
Nongrowing season	November 1 through March 31 (151 days)
Reporting year for annual loading rates	November 1 through October 31
Operator certification and endorsement	The wastewater treatment facility and reuse system must be operated by personnel certified and licensed in the State of Idaho wastewater operator training program at the operator class level specified in IDAPA 58.01.16.203 and properly trained to operate and maintain the system.
Disinfection limits in recycled water	Class C: The median number of total coliform organisms does not exceed 23 total coliform organisms/100 mL, as determined from the bacteriological results of the last five days for which analyses have been completed. No sample will exceed 230 total coliform organisms/100 mL in any confirmed sample.
Crop or vegetation allowed	Cropping must follow the most recently approved cropping plan.
Grazing	Prior to grazing, the permittee must submit a grazing management plan and receive written approval from DEQ.
Posting	Post signs around the perimeter of the irrigation site stating "Recycled Water - Do Not Enter" or equivalent signage both in English and Spanish. Signs to be posted every 500 feet and at each corner of the outer perimeter of the irrigated site. Signs are required where management unit border areas are accessible to the public.
Fencing	MU-047-01: Three-wire fencing
Construction plans	Pursuant to Idaho Code §39-118, IDAPA 58.01.16, and IDAPA 58.01.17, detailed plans and specifications must be submitted to DEQ for review and approval before construction, modification, or expansion of any wastewater treatment, storage, conveyance structures, groundwater monitoring wells, or reuse facility. Inspection requirements must be satisfied, and within 30 days of completion of construction, the permittee must submit as-built plans or a letter from an Idaho Professional Engineer certifying the facilities or structures were constructed in substantial accordance with the approved plans and specifications.

Category	Permit Limits and Conditions
Records retention requirements	Keep records generated to meet the requirements of this permit for the duration of the permit, including administrative extensions, plus two years.
Backflow prevention and testing requirements	Backflow prevention is required to protect surface water and ground water from an unauthorized discharge of recycled water or wastewater. Refer to section 9.1.1 of this permit.
Evaporators	<p>Prior to evaporator use, the permittee must submit an evaporator management plan and receive written approval from DEQ. Evaporator use must follow the most recently approved evaporator management plan.</p> <p><u>Maximum Hydraulic Loading:</u> None.</p> <p><u>Months of Operation:</u> The allowed months of operations must be determined in the evaporator management plan.</p> <p><u>Disinfection:</u> The evaporator must use recycled water that meets the disinfection requirements determined in the evaporator management plan.</p> <p><u>Wind speed limits:</u> Wind speed limits must be determined in the evaporator management plan.</p> <p><u>Reporting:</u> The total annual water volume to the evaporator must be reported and submitted with the annual report.</p>

5. Monitoring Requirements

5.1 Recycled Water and Supplemental Irrigation Water Sampling and Analyses

5.1.1 Constituent Monitoring

Monitoring Point Serial Number and Location	Sample Description	Sample Type and Frequency	Constituents (mg/L unless otherwise specified)
WW-047-01 Recycled water from lagoon LG-047-04 at discharge sample port.	Recycled water to MU-047-01	Grab sample/weekly during periods of use.	Total coliform (organisms/100 mL) Free chlorine residual ^a
WW-047-01 Recycled water from lagoon LG-047-04 at discharge sample port.	Recycled water to MU-047-01	Grab sample/monthly during periods of use	Total nitrogen, as N Total phosphorus, as P Total Dissolved Solids (TDS) (ppm) Volatile Dissolved Solids (VDS) pH (s.u.)
SW-047-01 Irrigation Canal discharge line sample port.	Supplemental irrigation water	Grab sample/every five years	Total nitrogen, as N Total phosphorus, as P TDS (ppm)

- a. The free chlorine residual should be a field reading taken at the same time as weekly total coliform sample collection. Data is to be logged and included in annual reports.

5.1.2 Management Unit and Other Flow Monitoring

Management Unit or Flow Measurement Serial Number and Location	Sample Description	Sample Type and Frequency	Parameters, each MU or FM
MU-047-01 Flow meter at irrigation pump	Recycled water flow from LG-047-04	Daily meter reading Monthly compilation of data	Volume (MG/month) Application depth (inches/month)
MU-047-01 Flow meter at irrigation pump	Supplemental irrigation water from canal	Daily meter reading Monthly compilation of data	Volume (MG/month) Application depth (inches/month)

5.2 Groundwater Monitoring

5.2.1 Groundwater Monitoring Point Descriptions

Monitoring Point Serial Number	Common Designation	Well Type	Gradient Location
GW-047-01	MW 1	Monitoring well	Upgradient
GW-047-02	MW 2	Monitoring well	Downgradient
GW-047-03	MW 3	Monitoring well	Midgradient
GW-047-04	MW 4	Monitoring well	Midgradient

5.2.2 Ground Water Monitoring, Sampling, and Analyses

Monitoring Point Serial Number	Sampling Point Description	Sample Type and Frequency	Constituents (mg/L unless otherwise specified)
GW-047-01 through GW-047-04	Monitoring wells	Field parameters/twice annually: prior to irrigation season (canal filling), and after irrigation season but prior to canal draining.	Water table elevation (feet) Water table depth (feet) pH (Standard Units) Specific conductance/electrical conductivity (µmhos/cm) Temperature (°C)
		Unfiltered grab sample/twice annually: prior to irrigation season (canal filling), and after irrigation season but prior to canal draining.	Nitrate-nitrogen, as N Phosphorus, as P Fecal Coliform ^a (cfu/100 mL) TDS (ppm)

- a. If the primary groundwater quality standard for fecal coliform is exceeded, the facility must contact DEQ to determine if additional analysis must be conducted.

5.3 Soil Monitoring

5.3.1 Soil Monitoring Unit Descriptions

Monitoring Point Serial Number	Description	Associated Management Unit
SU-047-01	Complete 77 acres	MU-047-01

5.3.2 Soil Monitoring, Sampling, and Analyses

Monitoring Point Serial Number	Sample Type	Sample Frequency	Constituents (Units in mg/kg Soil Unless Otherwise Specified)
SU-047-01	Composite samples ^a	Annually, March	Electrical conductivity (µmhos/cm in saturated paste extract) Nitrate, as N Ammonium, as N Plant available phosphorus pH (standard units)

- a. The number of sample locations PO or QAPP for each SU must be specified in the PO or QAPP. At each location, samples must be obtained from three depths: 0–12 inches, 12–24 inches, and 24–36 inches or refusal. The samples obtained from each depth must be composited by depth to yield three composite samples for each soil monitoring unit (one composite sample for each depth).

5.4 Crop Monitoring

5.4.1 Crop Harvest Monitoring

Associated Management Units	Sample Type	Sample Frequency	Parameters ^a
MU-047-01	Harvested portion, each crop, each MU	Each harvest	Crop type Harvest date Sample collection date Harvested acreage (acres) As-harvested ('wet') yield in customary harvested units (tons, bushels, cwt, etc.) As-harvested (field) moisture content (%) ^b Dry yield (lb)

- a. Documentation of reported yields must be provided for each harvest from each MU.
 b. The field moisture must be monitored at the time the harvested crop is weighed.

5.4.2 Plant Tissue Monitoring

Associated Management Units	Sample Type	Sample Frequency	Parameters ^a
MU-047-01	Harvested portion, each crop	Each harvest	Lab moisture content (%) ^b Total Kjeldahl nitrogen (%) Nitrate nitrogen, as N (ppm) Phosphorus as P (ppm) Ash (%)

- a. Plant tissue data may be determined by laboratory analysis or from standard tables. For data obtained from laboratory analysis, report dry-basis results for all parameters except laboratory moisture content.
- b. The plant tissue sample must be taken from the harvested portion of each crop at the time the crop is harvested or just prior to harvesting.

5.5 Lagoon Information

Serial number	Description	Surface Area, acres	Maximum Operating Volume, MG	Liner Type
LG-047-01	Cell 1; aerated	3.9	5.539	Bentonite
LG-047-02	Cell 2; aerated	2.2	2.672	Bentonite
LG-047-03	Cell 3; facultative	2.0	2.411	Bentonite
LG-047-04	Cell 4; facultative	2.0	3.324	Bentonite
LG-047-05	Cell 5; storage	8.2	32.5	HDPE

6. Reporting Requirements

6.1 Annual Report Requirements

The permittee must submit to DEQ an annual report prepared by a competent environmental professional covering the previous reporting year.

6.1.1 Due Date

The annual report is due no later than January 31 of each year, which must cover the previous reporting year.

6.1.2 Required Contents

The annual report must include the following:

1. Detailed results of the required monitoring as described in section 5 of this permit. The report must present all monitoring data in summary tables to expedite review. If the permittee monitors any parameter for compliance purposes more frequently than required by this permit, the results of this monitoring must be included in the calculation and reporting of the data submitted in the annual report.
2. A brief interpretive discussion of the results of all required monitoring data as specified by section 5. The discussion must address data quality objectives, validation, and verification; explain what the data say about permit compliance; and reuse facility environmental impacts. The reporting year for this permit is specified in section 4.5.
3. Status of all work described in section 3 of this permit.
4. Results of all backflow testing, repairs, and replacements required by section 9.1.1 of this permit.
5. Discussion of major maintenance activities such as major equipment replacement, lagoon liner maintenance, and wastewater treatment and reuse facility maintenance.
6. A summary of all noncompliance events that occurred during the reporting year. Examples of noncompliance events that must be discussed include but are not limited to: exceedance of permit limits, complaints, missed monitoring events, incorrect monitoring dates or frequencies, dry monitoring wells, uncontained spills causing runoff, construction without DEQ engineering plan approval, construction without engineering inspection, and reporting incorrect acreage.
7. Laboratory analytical reports that show results, analytical methods, and practical quantitation limits for monitoring specified in section 5 of the permit. Chain of custody forms, supporting information for laboratory analytical reports, and quality assurance documentation must be available for review upon request by DEQ.
8. The calculations and results for the parameters in the following table:

Monitoring Point Serial Number	Parameter (Calculate for each MU)	Units
MU-047-01	Recycled water loading rate	MG/month Inches/month
	Supplemental irrigation water loading rate	MG/month Inches/month
	IWR for each crop grown	Inches/month Inches/growing season
	Recycled water nitrogen and phosphorus loading rates	lb/(acre·year)
	Supplemental irrigation water nitrogen and phosphorus loading rates	lb/(acre·yr)
	Fertilizer nitrogen and phosphorus application rates, reported as elemental N and P	lb/(acre·yr)
	Waste solids nitrogen and phosphorus application rates	lb/(acre·yr)
	Crop harvest and yield, report for each harvest and the annual totals for each MU.	Crop types harvested Total harvested area (acres) Total wet yield (lb/yr, lb/(acre·yr)) Total dry yield (lb/yr, lb/(acre·yr))
	Crop nitrogen, phosphorus, and ash removal rates (dry-basis) Report each harvest and the annual totals for each MU.	lb N/(acre·yr) lb P/(acre·yr) lb Ash/(acre·yr)
Other Reporting Requirements: 1. Calculate nitrogen loading limits for next reporting year according to the requirements of section 4.3.		

6.1.3 Submittals

All applications, annual reports, or other information submitted to DEQ as required by this permit must be signed and certified as follows:

1. Permit applications must be signed by the responsible official as described below:
 - a. For a corporation by a responsible corporate officer.
 - b. For a partnership or sole proprietorship by a general partner or the proprietor, respectively.
 - c. For a municipality, state, federal, Indian tribe, or other public agency by either the principal executive officer, ranking elected official, or a person of decision-making authority who can legally bind the permittee with respect to the permit.
2. Annual reports and other information required by this permit must be signed by the responsible official or by a duly authorized representative of that person. A person is a duly authorized representative only if all of the following are true:

- a. The authorization is made in writing by the responsible official.
- b. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual having overall responsibility for environmental matters for the company.
- c. The written authorization is submitted to DEQ.

Submit all applications, annual reports, and other information required by this permit to the following DEQ regional office at this address:

Engineering Manager
Idaho Department of Environmental Quality
Idaho Falls Regional Office
900 N Skyline, Suite B
Idaho Falls, ID 83402

The annual report, or any other data or monitoring information submitted to DEQ, must include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative:

"I certify that the information provided in this submittal was prepared in conformance with the current Quality Assurance Project Plan and is to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01 or other enforcement action as provided for under Idaho law."

Permit applications must include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official:

"I certify that the information provided in this submittal is, to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01, non-issuance of the permit, or other enforcement action as provided for under Idaho law."

Other information submitted to DEQ as required by the permit must include the above certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative.

6.2 Emergency and Noncompliance Reporting

The permittee must report noncompliance incidents to DEQ's regional office at (208) 528-2650.

The permittee may also be required to report unauthorized discharges to surface waters to DEQ's IPDES program. The DEQ IPDES hotline is (833) IPDES24 or (833) 473-3724.

In case of public health emergencies, the permittee should call the 24-hour Idaho Emergency Medical Services Communications Center number at (800) 632-8000.

Section 8 of this permit and IDAPA 58.01.17.500.04 provide the reporting requirements for facilities.

The permittee must report all instances of permit non-compliance that may endanger public health or the environment and unauthorized discharges to surface waters of the State of Idaho to DEQ's regional office by telephone (phone numbers provided in this section) within 24 hours from the time the permittee becomes aware of these events at the phone numbers provided in this section.

The permittee must provide a written follow-up to the DEQ regional office within five days from the time the permittee became aware of the permit non-compliance or unauthorized discharge.

7. Reserved

8. Standard Permit Conditions

The following standard permit conditions are included as terms of this permit as required by the "Recycled Water Rules," (IDAPA 58.01.17.500).

500. STANDARD CONDITIONS.

Permit conditions will protect human health and the environment from the potential hazard of an existing or proposed wastewater treatment system. The permittee must comply with all conditions of the permit. The following conditions apply to and are included in all permits. (4-6-23)

01. Facility Operation. At all times, the permittee must properly maintain and operate all structures, systems, and equipment installed or used by the permittee for treatment, control, and monitoring to achieve compliance with the permit or these rules. (4-6-23)

02. Provide Information. If requested by the Department, the permittee must provide the Department, within a reasonable time, information including copies of records, to help the Department determine whether cause exists for modifying, revoking, re-issuing, or terminating the permit, or to determine compliance with the permit or these rules. (4-6-23)

03. Entry and Access. The permittee must allow the Department, consistent with Title 39, Chapter 1, Idaho Code, to: (4-6-23)

a. Enter the permitted facility and all associated property; (4-6-23)

b. Inspect any records kept under the conditions of the permit; (4-6-23)

c. Inspect and photograph any permitted facility, equipment, practice, records, or operation; and (4-6-23)

d. Sample or monitor any substance or any parameter at the facility to ensure permit compliance. (4-6-23)

04. Reporting. The permittee must report to the Department as specified in this section. (4-6-23)

a. A written report submitted at least thirty (30) days before: (4-6-23)

i. Any planned physical or operational alteration to the permitted facility that results or would result in a significant change in information submitted during the application process. If a major permit modification is needed, the alteration cannot be made before the Department issues approval. (4-6-23)

ii. Any anticipated change that would result in noncompliance with any permit condition or these rules. (4-6-23)

b. Orally within twenty-four (24) hours from the time the permittee became aware of any noncompliance that may endanger human health and the environment at telephone numbers provided in the permit. (4-6-23)

c. A written report as soon as possible, but within five (5) days of the date the permittee knows, or should reasonably know, of any noncompliance unless extended by the Department, providing: (4-6-23)

i. Description of the noncompliance and its cause; (4-6-23)

ii. Period of noncompliance including, to the extent possible, times and dates, if the noncompliance has not

been corrected, and the anticipated length of time it is expected to continue; and (4-6-23)

iii. Steps taken or planned, including timelines, to reduce or eliminate the continuance or reoccurrence of the noncompliance. (4-6-23)

d. In writing as soon as the permittee knows, or should reasonably know, of material facts not submitted or corrections to information submitted in a permit application, report, or notice provided to the Department. (4-6-23)

e. No person may knowingly make any false statement, representation, or certification in any form, notice, or report required under any permit, or any applicable rule or order in force pursuant thereto. (4-6-23)

05. Minimize Impacts. The permittee must take all necessary actions to eliminate and correct any adverse impact on human health and the environment resulting from permit noncompliance. (4-6-23)

06. Applied Waters Restricted to Premises. Wastewater or recycled water applied to the land surface must be restricted to the premises of the reuse site. (4-6-23)

07. Hazard or Nuisance Prohibited. Wastewater or recycled water must not create a public health hazard or a nuisance condition. (4-6-23)

08. Renewal. If the permittee intends to continue operating the permitted facility after the existing permit expires, the permittee must apply for a permit renewal according to these rules. (4-6-23)

9. General Permit Conditions

The following general permit conditions are based on the cited rules at the time of issuance and are enforceable as part of this permit. Note that the rules cited in this section, and elsewhere in this permit, are supplemented by the rules themselves. Rules applicable to your facility are enforceable whether or not they appear in this permit.

9.1 Operations

9.1.1 Backflow Prevention

Reuse facilities with existing or planned cross-connections or interconnections between the recycled water system and any water supply (potable or nonpotable) or surface water, must have backflow prevention assemblies, devices, or methods as required by applicable rule or as specified in this permit and approved by DEQ.

For public water systems, backflow assemblies must meet the requirements of IDAPA 58.01.08.543. Assemblies must be adequately maintained and must be tested annually by a certified backflow assembly tester, and repaired or replaced as necessary to maintain operational status.

Domestic water and irrigation water supply wells must meet the requirements of IDAPA 37.03.09.36 for preventing any waste or contamination of the groundwater resource. Backflow prevention assemblies or devices used to protect the groundwater must be adequately operated and maintained.

Discharge of recycled water to surface water is regulated by the DEQ or EPA. An IPDES or NPDES permit is required for any discharge to surface water and backflow prevention must be implemented to prevent any unauthorized discharge. Backflow prevention assemblies or devices used to protect surface water must be adequately operated and maintained.

Records of all testable backflow assembly test results, repairs, and replacements must be kept at the reuse facility along with other operational records, and must be discussed in the annual report and made available for inspection by DEQ. Other approved means of backflow prevention, such as siphons and air-gap structures that cannot be tested, must be maintained in operable order.

9.1.2 Restricted to Premises

Wastewaters or recharge waters applied to the land surface must be restricted to the premises of the application site. Wastewater discharges to surface water require an IPDES or NPDES permit (IDAPA 58.01.16.600.02).

9.1.3 Solids Management

Biosolids are the nutrient-rich organic materials resulting from the treatment of sewage sludge. When treated and processed, sewage sludge becomes biosolids that can be safely recycled and applied as fertilizer to sustainably improve and maintain productive soils and stimulate plant growth.

Biosolids generated from sewage sludge are regulated by DEQ or EPA under 40 CFR Part 503 and require a DEQ-approved sludge disposal plan as outlined in IDAPA 58.01.16.650. Contact DEQ before to applying biosolids at any permitted reuse facility.

Sludge is the semi-liquid mass produced and removed by wastewater treatment processes. This does not include grit, garbage, and large solids.

Sludge may be generated by wastewater treatment processes at municipal and industrial facilities. A DEQ-approved sludge disposal plan, as outlined in IDAPA 58.01.16.650, may be required.

Solid waste is any garbage or refuse, sludge from a waste water treatment plant, water supply treatment plant, or air pollution control facility and other discarded material including solid, liquid, semi-solid, or contained gaseous material resulting from industrial, commercial, mining, and agricultural operations and from community activities, but does not include solid or dissolved materials in domestic sewage, or solid or dissolved material in irrigation return flows or industrial discharges that are point sources subject to permits under Section 402 of the Federal Water Pollution Control Act, as amended or source, special nuclear, or by-product material as defined by the Atomic Energy Act of 1954, as amended.

Solid waste does not include inert wastes, manures and crop residues ultimately returned to the soils at agronomic rates, and any agricultural solid waste that is managed and regulated pursuant to rules adopted by the Idaho Department of Agriculture. DEQ reserves the right to use existing authorities to regulate agricultural waste that impacts human health or the environment.

Solid waste is regulated under the "Solid Waste Management Rules" (IDAPA 58.01.06). Wastes otherwise regulated by DEQ (i.e., this permit) are not regulated under IDAPA 58.01.06.

Waste solids include sludge and wastes otherwise regulated by DEQ according with IDAPA 58.01.06.001.03.a.xii. Waste solids may include vegetative waste, silt and mud containing organic matter, and other non-inert solid wastes.

Inert wastes are defined as non-combustible, nonhazardous, and non-putrescible solid wastes that are likely to retain their physical and chemical structure and have a de minimis potential to generate leachate under expected conditions of disposal, which includes resistance to biological attack.

Waste solids require a DEQ-approved sludge disposal plan as outlined in IDAPA 58.01.16.650.

9.1.4 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801)

Temporary cessation of operations and closure must be addressed as follows:

01. Temporary Cessation. A permittee must implement any applicable conditions specified in the permit for temporary cessation of operations. When the permit does not specify applicable temporary cessation conditions, the permittee must notify the Department before a temporary cessation of reuse operations at the facility greater than sixty (60) days in duration and any cessation not for regular maintenance or repair. Cessation of operations necessary for regular maintenance or repair of a duration of sixty (60) days or less do not require Department notification under this section. Notification compliance under this section includes a proposed temporary cessation plan to ensure the cessation of operations will not pose a threat to human health and the environment. (4-6-23)

02. Closure. A closure plan is required when a facility is closed voluntarily and when a permit is revoked. A permittee implements any applicable conditions specified in the permit for facility closure. Unless otherwise directed by the terms of the permit or by the Department, the permittee submits a closure plan to the Department for approval at least ninety (90) days before ceasing operations. The closure plan ensures the closed facility will not pose a threat to human health and the environment. Closure plan approval may be conditioned upon a permittee's agreement to complete such site investigations, monitoring, and any necessary remediation activities. A permittee must complete all closure plan activities. (4-6-23)

9.1.5 Plan of Operation (IDAPA 58.01.17.300.05)

The PO must comply with the following:

05. Reuse Facility Plan of Operation. A plan of operation must contain, as applicable, operation and management responsibility, permits and standards, general plant description, operation and control of unit operations, reuse area site maps, wastewater and recycled water characterization, cropping plan, hydraulic loading rate, constituent loading rates, compliance activities, seepage rate testing, site management plans, monitoring, site operations and maintenance, solids handling and processing, laboratory testing, general maintenance, records and reports, store room and inventory, personnel, and an emergency operating plan. Permittees are required to submit a plan of operation for review and approval. Amendments are also subject to review and approval. (4-6-23)

9.1.6 Seepage Testing Requirements (IDAPA 58.01.16.493.02.c)

Subsequent Tests. All lagoons covered under these rules must be seepage tested by an Idaho licensed professional engineer, an Idaho licensed professional geologist, or by individuals under their supervision every ten (10) years after the initial testing. (3-31-22)

9.1.7 Ground Water Quality Rule (IDAPA 58.01.11)

The permittee must comply with the requirements of the "Ground Water Quality Rule" (IDAPA 58.01.11).

9.2 Administrative

Requirements for administration of the permit are defined as follows.

9.2.1 Permit Modification (IDAPA 58.01.17.700)

01. Causes. A permit modification may be initiated by a permittee through a modification request or by the Department if one (1) or more of the following causes exist. (4-6-23)

a. Material and substantial alterations or additions to the permitted facility or activity occurred after permit issuance which justify applying permit conditions that are different or absent in the existing permit. (4-6-23)

b. Standards or regulations on which the permit was based amended by promulgation or by judicial decision after the permit was issued. (4-6-23)

c. The Department determines good cause exists for modifying a compliance schedule or terms and conditions of a permit. (4-6-23)

d. Level of discharge of any pollutant that is not limited in the permit exceeds the level that may cause an adverse impact to surface or ground waters. (4-6-23)

e. Correct technical mistakes, such as errors in calculation, or mistaken interpretations of law made in determining permit conditions. (4-6-23)

f. When a treatment technology proposed, installed, and properly operated and maintained by the permittee fails to achieve the requirements of the permit. (4-6-23)

9.2.2 Permit Transferable (IDAPA 58.01.17.800)

01. General. A permit may be transferred only upon Department approval. No transfer is required for a corporate name change if the permittee, via secretary of state filings, can verify a change in name alone occurred. An attempted transfer is not effective until approved in writing by the Department. (4-6-23)

9.2.3 Permit Revocation (IDAPA 58.01.17.920)

01. Conditions. The Department may revoke a permit or coverage under a reuse general permit if the permittee violates any permit condition or these rules, or the Department becomes aware of any omission or misrepresentation of condition or information relied upon when issuing the permit. (4-6-23)

02. Notice. Except in emergencies, the Department will issue a written notice of intent to revoke to the permittee before final revocation. Revocation becomes final within thirty-five (35) days of the permittee receiving notice unless, within that time, the permittee requests an administrative hearing in writing. The hearing is conducted according to IDAPA 58.01.23, Contested Case Rules and Rules for Protection and Disclosure of Records. (4-6-23)

03. Emergency Action. If the Department finds the human health, safety, or welfare requires emergency action, the Department will incorporate findings to support the action and issue a written notice of emergency revocation to the permittee. Emergency revocation is effective upon receipt by the permittee. If requested by the permittee in writing, the Department will provide the permittee a revocation hearing. Hearings are conducted according to IDAPA 58.01.23, Contested Case Rules and Rules for Protection and Disclosure of Records. (4-6-23)

04. Revocation and Closure. A permittee must perform the closure requirements in a permit and these rules and complete all closure plan activities regardless of the permit revocation. (4-6-23)

9.2.4 Severability

The provisions of this permit are severable, and if a provision or its application is declared invalid or unenforceable for any reason, that declaration will not affect the validity or enforceability of the remaining provisions.

10. Other Applicable Laws

DEQ may refer enforcement of the following provisions to the state agency authorized to enforce that rule. The permittee must comply with all applicable provisions identified in this section. Compliance with this permit does not relieve the permittee from applicable requirements in other federal, state, and local laws, statutes, and rules.

10.1 Owner Responsibilities for Well Use and Maintenance

10.1.1 Well Use

The well owner must not operate any well in a manner that causes waste or contamination of the groundwater resource. Failure to operate, maintain, knowingly allow the construction of any well in a manner that violates these rules, or failure to repair or properly decommission (abandon) any well as herein required will subject the well owner to civil penalties as provided by statute. See IDAPA 37.03.09.036.01 and consult the Idaho Department of Water Resources (IDWR) for more information.

10.1.2 Well Maintenance


The well owner must maintain the well to prevent waste or contamination of groundwaters through leaky casings, pipes, fittings, valves, pumps, seals, or through leakage around the outside of the casings, whether the leakage is above or below the land surface. Any person owning or controlling a noncompliant well must have the well repaired by a licensed well driller under a permit issued by the IDWR director according to the applicable rules. See IDAPA 37.03.09.036.02 and consult IDWR for more information.

10.1.3 Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Groundwater Resource

The well owner must have any well shown to pose a threat to human health and safety or cause contamination of the groundwater resource immediately repaired or decommissioned (abandoned) by a licensed well driller under a permit issued by the IDWR director according to the applicable rules. See IDAPA 37.03.09.036.06 and consult IDWR for more information.

11. Site Maps

11.1 Regional Map



11.2 Facility Map

